



14 August, 2007

Emerson Process Management
Rosemount Inc.
8200 Market Blvd
Chanhassen, MN U.S. 55317-9786

Certificate of Hydrostatic Testing - Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: Customer Name Here PO: 1234567	Manufacturer Information Sales Order: 1234567 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: PIT-12057X Serial No: 9984422 Model No: 3051CG5A02A1KM611P1S5Q4 Module Serial No: 9957156 Output: Linear	Test Information Factory: CHANHASSEN, MN, USA Operator ID: 15123 Test Date: 5/1/2007 10:14:02AM

Target Pressure		Applied Pressure		Test Result
PSI	BAR	PSI	BAR	
3000.00	206.84	3000.00	206.84	Pass

This is to certify that the listed serialized equipment was hydrostatically tested per Rosemount Inc. Test procedure GP1746. Pressure was applied for a minimum of 10 minutes. No leaks were observed.

Tim Layer
Vice-President of Global Quality