

Bristol ControlWave Pump Controller Application User's Guide

ControlWave



Contents

Chapter 1 – Introduction 1-1

1.1	Scope of this Manual	1-1
1.2	Overview	1-2

Chapter 2 – Installation 2-1

2.1	Before You Begin	2-1
2.2	Downloading the Application from the Web Site	2-2
2.3	Installing the Application	2-2
2.4	Updating an Existing Controller with the Pump Controller Application	2-9
2.4.1	Loading the Flash Configuration Profile (FCP) File	2-10
2.4.2	Downloading the ControlWave Project	2-13

Chapter 3 – Configuration 3-1

3.1	Starting the Configuration Wizard	3-3
3.2	Pump Configuration	3-4
3.2.1	Configure Pumps	3-5
3.3	Variable Frequency Drive (VFD) Configuration	3-6
3.3.1	Configure VFD	3-7
3.3.2	Configure Fixed Speed Pump Control	3-8
3.4	Single Loop Controller (SLC) Configuration	3-9
3.4.1	Configure the SLC	3-10
3.5	Station Flow	3-11
3.5.1	Configure Flow Input	3-13
3.5.2	Configure Estimated Flow Input	3-14
3.5.3	Configure Flow Totalization	3-15
3.6	Alarm Limit Configuration	3-17
3.7	Discharge Pressure Measurement and Control	3-19
3.7.1	Configure Discharge Pressure Input	3-20
3.7.2	Configure Discharge Pressure Control	3-21
3.7.3	Configure Discharge Pressure Override Control	3-22
3.8	Suction Pressure Measurement and Control	3-24
3.8.1	Configure Suction Pressure Input	3-25
3.8.2	Configure Suction Pressure Override	3-26
3.9	Local Tank Level Measurement and Control	3-28
3.9.1	Configure Level Input	3-29
3.9.2	Configure Level Control	3-31
3.9.3	Configure Level Override	3-32
3.10	Remote Tank Level Measurement and Control	3-34
3.10.1	Configure Level Input	3-35
3.10.2	Configure Level Control	3-36
3.10.3	Configure Level Override	3-37
3.11	Well Drawdown Level Measurement and Control	3-40
3.11.1	Configure Well Drawdown Level Input	3-41
3.11.2	Configure Well Drawdown Level Override	3-42
3.12	Time Control	3-44
3.12.1	Configure Timeclock Control	3-45
3.12.2	Configure Restricted Time of Use Override	3-47
3.13	Station Control	3-49
3.14	Chlorine Residual	3-51

3.14.1 Configure CL2 Residual Monitor Input.....	3-52
3.15 Configure pH Monitor	3-53
3.15.1 Configure pH Monitor Input.....	3-54
3.16 Chemical Feed Pump.....	3-55
3.17 Rain Gauge	3-56
3.17.1 Configure Rain Gauge Input	3-57
3.18 I/O Configuration	3-58
3.18.1 Configure All I/O	3-59
3.18.2 Configure CL2 Probe	3-64
3.18.3 Configure pH Probe	3-65
3.19 Recipe	3-66
3.19.1 Creating a Recipe	3-67
3.19.2 Changing the Floating Point Format of Values	3-68
3.19.3 Saving the Recipe	3-69
3.19.4 Recalling a Saved Recipe, and Sending Its Values to the Pump Controller	3-69
3.20 Saving the Configuration.....	3-70

Chapter 4 – Start Up **4-1**

4.1 I/O Checkout	4-2
4.2 SLC Tuning	4-3
4.3 Pump Checkout.....	4-4
4.3.1 Permissive and Interlock Details.....	4-7

Chapter 5 – Operation **5-1**

5.1 Fixed Speed (FS) Pump Control Settings.....	5-2
---	-----

Chapter 6 – Logs **6-1**

6.1 View Archives.....	6-2
6.2 View Audit Trail	6-6
6.2.1 Data Storage	6-7
6.2.2 Search Criteria	6-8
6.3 Collection	6-9

Chapter 1 – Introduction

This manual explains how to install and configure the ControlWave Pump Controller application. This application may be used with either ControlWave MICRO or ControlWave Express controllers.

Chapter 1 details the structure of the manual, and discusses the basic features of the ControlWave Pump Controller application.

In This Chapter

1.1	Scope of this Manual	1-1
1.2	Overview	1-2

1.1 Scope of this Manual

This manual is divided up into the following chapters:

Chapter 1 Introduction	Describes the organization of the manual, and the basic features of the ControlWave Pump Controller application.
Chapter 2 Installation	Describes how to install the ControlWave Pump Controller pages on your PC.
Chapter 3 Configuration	Describes how to use the configuration menus of the application to configure the ControlWave Pump Controller.
Chapter 4 Start Up	Describes how to use the startup menus of the ControlWave Pump Controller application.
Chapter 5 Operation	Describes how to use the operation menus of the ControlWave Pump Controller application.
Chapter 6 Logs	Describes how to retrieve historical data (archive files, audit trail data) from the ControlWave Pump Controller.

Other relevant documentation you may need to refer to:

For help on this:

Refer to these document(s):

Installing the controller hardware, wiring I/O, connecting communication cables to the PC, etc.	Depending upon the type of controller model you purchased, either CI-ControlWave MICRO -or- CI-ControlWaveExpress
Using portions of the TechView software related to calibration or on-line editing.	TechView User's Guide (D5131)

1.2 Overview

The Emerson ControlWave Pump Controller is a pre-programmed application that may be configured by the user to perform a variety of pump station control actions.

These actions include starting and stopping up to 3 fixed speed pumps based on:

- a local or remote tank level indication,
- tank floats,
- local discharge and suction pressure,
- well drawdown level and
- time of day.

In addition, the fixed speed pumps may be operated to supplement a single variable frequency drive (VFD) pump.

The VFD may be operated to maintain either flow or discharge pressure setpoints.

The ControlWave Pump Controller monitors other typical parameters at a pump station, including chlorine residual, pH, and intrusion alarms.

The ControlWave Pump Controller generates alarms when any of these parameters exceed operator specified alarm limits, and maintains historical information (minimum, maximum, and averages or totals) on an hourly and daily basis.

There is no programming required to use the ControlWave Pump Controller. The user configures the controller using OpenBSI TechView, which presents operator menus for performing configuration, monitoring, and operating the pump station. Initial configuration can be done using the Configuration Wizard, which presents the user with a series of questions to be answered. After configuring the initial site, configuring additional sites can be performed by copying a previous configuration into the new ControlWave Pump Controller.

The ControlWave Pump Controller is available in the following configurations:

Platform	I/O Boards	Configuration
ControlWave MICRO	2 Mixed I/O Boards	CWM_2M
ControlWave MICRO	1 Mixed I/O Board 1 Mixed DI/O Board	CWM_1M_1D
ControlWave MICRO	1 Mixed DI/O Board 1 Mixed AI/O Board	CWM_1D_1A
ControlWave Express PAC	1 I/O Expansion Board	MPMP_1_0_D

Each of these configurations comes standard with two (2) RS-232 ports and one (1) RS-485 port. An Ethernet port can be added as an option to each.

A Keypad/Display is available as an option with each of these units.

The available I/O for each configuration is shown below:

Configuration	DI	DO	DI/O	AI	AO	HSC	CNT/DI
CWM_2M	0	0	12	8	2	4	0
CWM_1M_1D	12	4	6	4	1	2	0
CWM_1D_1A	12	4	0	6	2	0	0
ExpressPAC	4	2	2	3	1	2	2

Chapter 2 – Installation


Chapter 2 discusses some preliminary activities which must be performed before you start, and then covers the process of loading the ControlWave Pump Controller application pages onto your PC.

In This Chapter

2.1	Before You Begin.....	2-1
2.2	Downloading the Application from the Web Site	2-2
2.3	Installing the Application	2-2

2.1 Before You Begin

Verify that the latest version of OpenBSI or BSIConfig is installed on your PC. To confirm that the software is installed, click on **Start → Programs** and look for a program group called OpenBSI or BSIConfig



Verify that the ControlWave Pump Controller is wired to the field devices and power is applied to the unit.

2.2 Downloading the Application from the Web Site

In your Internet browser, go to the Remote Automation Solutions web site, at the following address:


http://www.bristolbabcock.com/services/members/application_files/ap_controlwave_std_programs.htm

Download the file PUMP_APP.EXE, and save it on your desktop

2.3 Installing the Application

STEP 1

Double-click on the MPMP_1_0.EXE icon (saved as an icon on your desktop in the previous step.).



STEP 2

Click on Unzip to extract the required files to the C drive. The program will automatically install the required files in the C:\OpenBSI\WebWaterApp folder. If this folder does not exist, it will be created. Close the WinZip Self Extractor.

STEP 3

Two Icons will now be available from the Desktop – mH2OIP.tvcs is used to connect to the ControlWave Pump Controller via Ethernet and mH2OSerial.tvcs is used to connect to the ControlWave Pump Controller via a serial RS-232 connection.



If you have purchased a ControlWave Pump Controller, or have already re-configured your ControlWave Micro or ControlWave Express as a ControlWave Pump Controller, proceed to [STEP 4](#).

To reconfigure a previously purchased ControlWave Micro or ControlWave Express as a ControlWave Micro Pump Controller, proceed to the instructions in Sections 2.4.1 and 2.4.2 then return to STEP 4.

STEP 4

To connect to a ControlWave via a serial RS-232 connection, connect a null modem serial cable (P/N 392843-01-3) between a serial port on your PC and COM1 (the C1 port) on the ControlWave Micro or ControlWave Express. If you don't have a null modem serial cable, you can build one according to the instructions in the controller's hardware manual. After the connection is made, proceed to [STEP 5A](#)


If you wish to connect to the ControlWave Pump Controller using Ethernet, and if the desired IP Address of the Controller has already been set in the Controller, make an Ethernet connection between the PC and the Controller. This can be done by connecting a null modem Ethernet cable directly between the Ethernet Port on the Controller and the Ethernet Card on your PC, or connecting an Ethernet patch cable between the Controller and an Ethernet Switch and a second patch cable between the Ethernet Switch and the PC. Please proceed to [STEP 5B](#).

If the IP Address in the Controller has not been set, follow the instructions in Section 2.4.1 and then return to STEP 5B.

STEP 5A

Start TechView by double clicking on the mH2OSerial.tvb shortcut on the Desktop.

Ignore the question regarding the number of runs.



The dialog box titled "Runtime Configuration Parameters" has a blue title bar. It contains four configuration questions, each with a corresponding input field or dropdown menu:

- Question: "How many runs does the RTU's application load support ?" Input: "1"
- Question: "What is the Local Address of the RTU that you like to connect to ?" Input: "1" (dropdown menu)
- Question: "What port would you like to use ?" Input: "COM1" (dropdown menu)
- Question: "What baud rate would you like to use ?" Input: "115200" (dropdown menu)


At the bottom center is an "OK" button.

By default, the TechView session assumes the Local Address of the unit is 1. If you have previously changed the Local Address of the ControlWave Pump Controller, select the correct address from the drop down menu.

By default, the TechView session uses COM1 from your PC. If the communications port being used on your PC is a port other than COM1, change it by using the drop down menu.

By default, the TechView session communicates at a baud rate of 115200. It is strongly recommended that you use this speed to communicate with the ControlWave Pump Controller via TechView. If it was necessary to change the baud rate of the ControlWave Pump Controller, select the proper baud rate from the drop down menu.

Click on OK.



The dialog box titled "SignOn to RTU" has a blue title bar and a red close button. It displays the status "Node currently off-line" next to a small icon of a person with a speech bubble. Below this are two input fields:

- Username: "SYSTEM"
- Password: "XXXXXX"

At the bottom are two buttons: "Signon" and "Cancel".

You will be prompted for a Username and Password. By default, the Username is SYSTEM and the Password is 666666. Enter the Username and Password and click on Signon.


Proceed to [STEP 6](#)

STEP 5B

Start TechView by double clicking on the mH2OIP.tvcs shortcut on the Desktop.

Enter the IP Address of the Pump Controller.

Click on OK.



The screenshot shows a dialog box titled "Runtime Configuration Parameters". It contains four input fields: "How many runs does the RTU's application load support?" with the value "1"; "What is the IP Address of the RTU that you like to connect to?" with the value "10 . 211 . 73 . 240"; "What port would you like to use?" with a dropdown menu showing "COM1"; and "What baud rate would you like to use?" with a dropdown menu showing "115200". There is an "OK" button at the bottom right.

You will be prompted for a Username and Password. By default, the Username is SYSTEM and the Password is 666666. Enter the Username and Password and click on Signon.




The screenshot shows a dialog box titled "SignOn to RTU". It has a status bar that says "Status: Login required" with a small icon. Below this, there are two input fields: "Username:" with the value "SYSTEM" and "Password:" with the value "XXXXXXXXXX". There are "Signon" and "Cancel" buttons at the bottom.


Proceed to [STEP 6](#)

STEP 6

If TechView is successfully connected to the ControlWave Pump Controller, you should see the screen below. To start configuring the ControlWave Pump Controller, proceed to [STEP 7](#).



If TechView is unable to connect to the ControlWave Pump Controller, you will see the 'Node currently off-line' message. Verify that your communication configuration parameters are correct (address, port, etc.) are correct, and that cables are connected properly.




STEP 7

If you see the screen below, you have successfully connected to the ControlWave Pump Controller with TechView.


Along the right hand side of the screen are some icons.

 Calibration	NOTE: This option is not applicable to this application.
 On Line Edits	Clicking on the On-Line Edits icon allow certain limited edits to be made to lists and archive files. For details on on-line edits, please see the <i>TechView User's Guide</i> (document# D5131).
 Station	Clicking on the Station icon allows you to call up the menus for configuring the ControlWave Pump Controller application.

Click on the **Station** icon.



By clicking on the System Information button, the following screen will be displayed.




SYSTEM INFORMATION

	<i>Actual</i>	<i>Recommended</i>
Web Page Version	V01:00:00	V01:00:00
CPU Type	CWM	CWM
PROM Version	V04:72:00	V04:72:00
IO Card Slot 1	Multi I/O 6-DIO 2-HSC 4-AI 1-AO	Multi I/O 6-DIO 2-HSC 4-AI 1-AO
IO Card Slot 2	Multi I/O 6-DIO 2-HSC 4-AI 1-AO	Multi I/O 6-DIO 2-HSC 4-AI 1-AO
Resource	CWM_2M	
Designer Project Name	MPMP_1_0	
Designer Project Version	V01:00:00	

Pump Station Controller

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

This page is a summary of System Information. A comparison of the CPU Type, Firmware Revision, and I/O cards is made between the actual and required. If everything is OK, the screen will appear as above. If there is a mismatch detected, some items will be highlighted, as shown in the screen below:



SYSTEM INFORMATION

	<i>Actual</i>	<i>Recommended</i>
Web Page Version	V01:00:00	V01:00:00
CPU Type	CWM	CWM
PROM Version	V04:60:00	V04:72:00
IO Card Slot 1	Multi I/O 6-DIO 2-HSC 4-AI 1-AO	Multi I/O 6-DIO 2-HSC 4-AI 1-AO
IO Card Slot 2	Multi I/O 6-DIO 2-HSC 4-AI 1-AO	Multi I/O 6-DIO 2-HSC 4-AI 1-AO
Resource	CWM_2M	
Designer Project Name	MPMP_1_0	
Designer Project Version	V01:00:00	

Pump Station Controller

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Before proceeding, any I/O card mismatches must be resolved.



WARNING

If you fail to resolve IO Card mismatches the ControlWave Pump Controller will not operate properly.

If you have a mismatched PROM version, verify that the actual PROM version is older than the desired PROM version (for instance, PROM version V04:60:00 is older than V04:72:00; PROM version V04:80:00 is newer than V04:72:00).

Using an older PROM Version or Web Page Version may cause some of the features of the ControlWave Pump Controller program to function improperly.

If you do have an older PROM version, you may upgrade by downloading the latest firmware from our web site:

www.bristolbabcock.com/services/members/application_files/Contract/flashware/controlwave_flashware.htm

In order to be able to download the latest firmware, you must be a Software Support Plan member. If you are unsure if you are a Software Support Plan member, please contact your local sales representative.

Close this page by clicking on the  button.


2.4 Updating an Existing Controller with the Pump Controller Application

If you have an existing ControlWave MICRO, or ControlWave Express, already installed in the field, with the required I/O, and want to update it to run the pump controller application, you will need to:


- Load the Flash Configuration Profile (FCP) file for the Pump Controller application.
- Download the appropriate ControlWave project into the unit.

2.4.1 Loading the Flash Configuration Profile (FCP) File

1. In TechView, click on **Operations → Access Flash Parameters**
-or- click on the 'Access Flash' icon, to start the Flash Configuration Utility.




2. In the Flash Configuration Utility, click on the **[Read Profile from File]** button.




Click on the **[Read Profile From File]** button

3. Choose the FCP file for the water application, located in the \OpenBSI\WebWaterApp\Config folder, and click on **[Open]**.




Choose the FCP file, then click on **[Open]**.

- The FCP file for the ControlWave Pump Controller application will be opened. If you need to set the proper IP address for the controller, click on the 'Ports' tab, and enter the address in the **"IP ADDR A:"** field.




- When you have completed any necessary edits, click on the **[Save to Rtu]** button.
- When prompted to confirm that you want to proceed, click **[Yes]**. The FCP file will be copied into the ControlWave for you.




2.4.2 Downloading the ControlWave Project

1. Right-click on the 'RTU' icon in TechView, and choose **"Downloader"** from the pop-up menu.




2. Click on the **[Browse Bootfile]** button, and navigate to the \MPMP_V_vv subfolder of the Downloads directory, where V is the major file version, and vv is the minor file version. **NOTE: In these examples, the version shown is 1_0D, however; your version will be different.**




Click on the **[Browse Bootfile]** button, and navigate to the \MPMP_V_vv folder.


- From that folder, you need to select the resource sub-folder which contains the project file (*.PRO) you need to download. (See Section 1.2 for details on the different resources.)



- Once you have selected the project which has the correct configuration for your hardware, click on it, then click on **[Open]**.



5. In the Downloader, enter a valid username/password combination for the controller, then click on **[Begin]**. The project (.PRO file) will be downloaded into the ControlWave unit.



Chapter 3 – Configuration

This chapter covers the steps necessary to configure the ControlWave Pump Controller application.


In This Chapter

3.1	Starting the Configuration Wizard.....	3-3
3.2	Pump Configuration	3-4
3.2.1	Configure Pumps.....	3-5
3.3	Variable Frequency Drive (VFD) Configuration	3-6
3.3.1	Configure VFD.....	3-7
3.3.2	Configure Fixed Speed Pump Control	3-8
3.4	SLC Configuration	3-9
3.4.1	Configure the SLC.....	3-10
3.5	Station Flow	3-11
3.5.1	Configure Flow Input	3-13
3.5.2	Configure Estimated Flow Input	3-14
3.5.3	Configure Flow Totalization.....	3-15
3.6	Alarm Limit Configuration	3-17
3.7	Discharge Pressure Measurement and Control	3-19
3.7.1	Configure Discharge Pressure Input.....	3-20
3.7.2	Configure Discharge Pressure Control	3-21
3.7.3	Configure Discharge Pressure Override Control.....	3-22
3.8	Suction Pressure Measurement and Control.....	3-24
3.8.1	Configure Suction Pressure Input	3-25
3.8.2	Configure Suction Pressure Override	3-26
3.9	Local Tank Level Measurement and Control.....	3-28
3.9.1	Configure Level Input	3-29
3.9.2	Configure Level Control.....	3-31
3.9.3	Configure Level Override	3-32
3.10	Remote Tank Level Measurement and Control.....	3-34
3.10.1	Configure Level Input	3-35
3.10.2	Configure Level Control.....	3-36
3.10.3	Configure Level Override	3-37
3.11	Well Drawdown Level Measurement and Control	3-40
3.11.1	Configure Well Drawdown Level Input.....	3-41
3.11.2	Configure Well Drawdown Level Override	3-42
3.12	Time Control	3-44
3.12.1	Configure Timeclock Control.....	3-45
3.12.2	Configure Restricted Time of Use Override	3-47
3.13	Station Control	3-49
3.14	Chlorine Residual	3-51
3.14.1	Configure CL2 Residual Monitor Input.....	3-52
3.15	Configure pH Monitor.....	3-53
3.15.1	Configure pH Monitor Input	3-54
3.16	Chemical Feed Pump	3-55
3.17	Rain Gauge.....	3-56
3.17.1	Configure Rain Gauge Input.....	3-57
3.18	I/O Configuration.....	3-58
3.18.1	Configure All I/O	3-59
3.18.2	Configure CL2 Probe.....	3-64
3.18.3	Configure pH Probe.....	3-65
3.19	Recipe.....	3-66
3.19.1	Creating a Recipe.....	3-67

3.19.2 Changing the Floating Point Format of Values	3-68
3.19.3 Saving the Recipe	3-69
3.19.4 Recalling a Saved Recipe, and Sending Its Values to the Pump Controller	3-69
3.20 Saving the Configuration	3-70

To configure the ControlWave Pump Controller, click on the Configure tab and then click on the Station Configuration Wizard button.

The System Information screen was discussed earlier in Section 2.3.



This will open the Configuration Wizard screens.

3.1 Starting the Configuration Wizard

The Station Configuration Wizard asks you questions to assist you in configuring the ControlWave Pump Controller.




WARNING

While configuring the ControlWave Pump Controller, the user will be able to change I/O assignments, modify start and stop setpoints, and adjust alarm limits, etc. It is up to the user to make sure that all equipment is made safe. Before putting the controller in the configuration mode, it is recommended that any associated processes be closed down or placed under manual control. This precaution will prevent any processes from accidentally running out of control while configuration is being done.

To start the Configuration Wizard, click on the **[Start?]** button. Clicking on the Start button does two things:



- It saves the current configuration in a temporary file on the ControlWave Pump Controller. This configuration may be restored at any time (See Section 3.20).
- It also allows the user to enter the Configuration Wizard screens. If the screen does not say Configuring, the user is not permitted to go forward in the configuration process.



There are two ways to navigate through the Configuration Wizard:


- Click on the NEXT button at the bottom of each page to sequentially move through the configuration, -or-
- Use the 'Select a Device' drop down menu, to choose a particular item to configure, and then click on Configure. *(This option is accessible from all of the main configuration pages, and allows the user to quickly navigate the system to make changes to a particular item.)*

3.2 Pump Configuration


The first screen allows the user to choose how many fixed speed pumps are included in the system. Selection of and configuration of the variable speed drive (VFD) will be done in a separate step.

The screenshot shows the 'Configuration Wizard' window. At the top, there is a title bar with 'Configuration Wizard' and a 'Select a Device' dropdown menu next to a 'Configure' button. Below this is a dark blue header bar with the word 'PUMPS' in white. Underneath, a light gray box contains the text 'How many pumps are there?' followed by a text input field containing '3 Pumps' and a dark blue button labeled 'CONFIGURE PUMPS'. At the bottom of the window, there is a navigation bar with three buttons: 'BACK', 'NEXT', and 'FINISH'. The footer of the window displays the 'Bristol ControlWave' logo, the text 'Pump Station Controller', and the 'EMERSON' logo. A small copyright notice is visible at the very bottom: '© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.'

To select the number of pumps to be included, right click on the data entry field (the white field with the black text), and left click on Change Signal Value.



This will bring up a drop down menu. You may choose none, 1, 2, or 3 Pumps, and then click on OK.



Once the number of pumps has been selected, the user may configure the pumps by clicking on the CONFIGURE PUMPS button.

3.2.1 Configure Pumps

Configuration Wizard - Pump Configuration

PUMP	MODE	START DELAY (Seconds)	RESPONSE TIME (Seconds)	MINIMUM RUNTIME (Seconds)	MAXIMUM STARTS/HOUR	MAXIMUM STARTS/DAY
PUMP 1	3 WIRE	0	10	0	2	48
PUMP 2	3 WIRE	0	10	0	2	48
PUMP 3	3 WIRE	0	10	0	2	48

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

From this screen, the user may provide a unique descriptor for each pump, and set other parameters for the pump controls.

Field	Description
MODE	The user may select between 2 WIRE or 3 WIRE. 2 WIRE control is used when there is a single maintained contact for starting the pump. 3 WIRE control is used when there is one momentary start contact and one momentary stop contact for starting and stopping the pump.
START DELAY (Seconds)	The amount of time, in seconds, that the program will wait after receiving a start command before it turns on the start DO.
RESPONSE DELAY (Seconds)	The amount of time, in seconds, that the program will wait for a positive indication that the pump has started or stopped after a start or stop DO is turned on.
MINIMUM RUNTIME (Seconds)	The amount of time, in seconds, that the pump will run after being started, even if a stop command is issued. The pump will be stopped immediately if the pump interlock conditions are not met.
MAXIMUM STARTS/HOUR, MAXIMUM STARTS/DAY	This represents the maximum starts per hour or day that will be allowed for the pump. After the maximum starts are attempted in a period, any additional start attempts will be ignored.

To return to the previous screen, click on BACK.

3.3 Variable Frequency Drive (VFD) Configuration

Configuration Wizard Select a Device Configure

VARIABLE FREQUENCY DRIVE

Is there a VFD used at this site? Yes No?

CONFIGURE VFD

Is the VFD Speed used for primary control of fixed speed pumps at this site? Yes No?

CONFIGURE FIXED SPEED PUMP CONTROL

BACK **NEXT** **FINISH**

Bristol ControlWave **Pump Station Controller** **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Clicking on CONFIGURE VFD will bring up a page similar to the page for configuring the pumps. (See 3.3.1)

The VFD speed may be used to control the operation of the fixed speed pumps. Typically, a fixed speed pump would be started if the VFD speed reached some high limit, and then the fixed speed pump would be stopped if the VFD speed reached some low limit. If this option is required click on CONFIGURE FIXED SPEED PUMP CONTROL. (See 3.3.2)

3.3.1 Configure VFD

Configuration Wizard - VFD Configuration

VFD CONTROL	MODE	START DELAY (Seconds)	RESPONSE TIME (Seconds)	MINIMUM RUNTIME (Seconds)	MAXIMUM STARTS/HOUR	MAXIMUM STARTS/DAY
VFD 1	2 WIRE	0	10	0	2	48

OUTPUT	ZERO	SPAN	UNITS
	0.0	100.0	Hz

BACK

Bristol ControlWave Pump Station Controller **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

The only difference between this page and the pump configuration page is that the analog output used to control the VFD is configured on this page.

Field	Description
MODE	The user may select between 2 WIRE or 3 WIRE. 2 WIRE control is used when there is a single maintained contact for starting the VFD. 3 WIRE control is used when there is one momentary start contact and one momentary stop contact for starting and stopping the VFD.
START DELAY (Seconds)	The amount of time, in seconds, that the program will wait after receiving a start command before it turns on the start DO.

RESPONSE DELAY (Seconds)	The amount of time, in seconds, that the program will wait for a positive indication that the VFD has started or stopped after a start or stop DO is turned on.
MINIMUM RUNTIME (Seconds)	The amount of time, in seconds, that the VFD will run after being started, even if a stop command is issued. The VFD will be stopped immediately if the pump interlock conditions are not met.
MAXIMUM STARTS/HOUR, MAXIMUM STARTS/DAY	This represents the maximum starts per hour or day that will be allowed for the VFD. After the maximum starts are attempted in a period, any additional start attempts will be ignored.
OUTPUT ZERO	This is the speed command sent to the VFD when the output is 4 mA or 1 Volt.
OUTPUT SPAN	The difference between the value of the speed command at 4 mA (or 1 volt) and its value at 20 mA (5 volts). For instance, if the ZERO is 5.0 Hz and the SPAN is 85.0 Hz, the SPAN is 80.0.
OUTPUT UNITS	This is the engineering units of the speed command.

To return to the VFD screen, click on BACK.

3.3.2 Configure Fixed Speed Pump Control

Configuration Wizard - Control Configuration

PUMPS AVAILABLE	3			
FIXED SPEED PUMP CONTROL BASED ON VFD SPEED				
VFD 1	0.0 %			
PUMP	START SETPOINT	STOP SETPOINT	START COMMAND	STOP COMMAND
LEAD	90.0	0.0	OFF	OFF
LAG 1	95.0	0.0	OFF	OFF
LAG 2	97.0	0.0	OFF	OFF

BACK




Pump Station Controller

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Depending on the number of fixed speed pumps configured, the user may assign up to three start setpoints and three stop setpoints, to control the operation of the fixed speed pumps.

Field	Description
START SETPOINT	If the actual VFD speed exceeds this value, the START COMMAND will be activated to start the associated fixed speed pump.
STOP SETPOINT	If the actual VFD speed falls below this value, the STOP COMMAND will be activated to stop the associated fixed speed pump.
START COMMAND	The START command is activated (and displays 'START' in this field) when the actual VFD speed exceeds the START SETPOINT. Otherwise, this field displays 'OFF'.
STOP COMMAND	The STOP command is activated (and displays 'STOP' in this field) when the actual VFD speed falls below the STOP SETPOINT. Otherwise, this field displays 'OFF'.

3.4 Single Loop Controller (SLC) Configuration

If there is a VFD being used, then the Single Loop Controller (SLC) function must be included to provide PID control to the VFD.

Configuration Wizard Select a Device Configure

SINGLE LOOP CONTROLLER (SLC).

Is there a single loop controller (SLC) used at this site? Yes No?

CONFIGURE THE SLC

BACK **NEXT** **FINISH**

Bristol ControlWave **Pump Station Controller** **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

To configure the Single Loop Controller click on CONFIGURE THE SLC. (See 3.4.1).

3.4.1 Configure the SLC

Configuration Wizard - Input Configuration

SINGLE LOOP CONTROLLER			ALARM LIMITS		
	SOURCE	ZERO	SPAN	UNITS	DESCRIPTION
PV1	FLOW	0.0	100.0	GPM	PV1 -FLOW
PV2	DISC PRESS	0.0	100.0	PSI	PV2 -DISCHARGE

	DESTINATION	ZERO	SPAN	UNITS	DESCRIPTION
MV	VFD1 SPEED	0.0	100.0	%	SLC OUTPUT

BACK

Bristol

ControlWave

Pump Station Controller

EMERSON

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
PV1/PV2 SOURCE	The source of each process variable may be selected from this list: Discharge Pressure, Suction Pressure, Local Level, Remote Level, Drawdown Level, Chlorine Residual, a Fixed Value, or Zero (0.0) <Signal Value> ST1.SLC1_PV1_SELECT ST1.SLC1_PV1_SELECT Old Value: FLOW New Value: FLOW Fixed Zero FLOW DISC PRESS SUCT PRESS LOCAL LEVEL REMOTE LEVEL DRAWDOWN CL2 RES OK Cancel Q-Data Off
PV1/PV2 ZERO	The value of the process variable (PV1 or PV2) at 4 mA or 1 volt.

PV1/PV2 SPAN	The difference between the value of the process variable (PV1 or PV2) at 4 mA (or 1 volt) and its value at 20 mA (5 volts). For instance, if the ZERO is 0.0 GPM and the flow rate at 20 mA is 150.0 GPM, the SPAN is 150.0. If the ZERO is 15.0 GPM and the flow rate at 20 mA is 150.0 GPM, the SPAN is 135.0.
PV1/PV2 UNITS	The engineering units of the process variable (PV1 or PV2).
PV1/PV2 DESCRIPTION	A textual description of the process variable (PV1 or PV2)
MV DESTINATION	The destination of the manipulated variable (MV) is currently the VFD1 speed.
MV ZERO	The value of the manipulated variable (MV) at 4 mA or 1 volt.
MV SPAN	The difference between the value of the manipulated variable (MV) at 4 mA (or 1 volt) and its value at 20 mA (5 volts). For instance, if the ZERO is 0.0 GPM and the flow rate at 20 mA is 150.0 GPM, the SPAN is 150.0. If the ZERO is 15.0 GPM and the flow rate at 20 mA is 150.0 GPM, the SPAN is 135.0.
MV DESCRIPTION	A textual description of the manipulated variable (MV).

Tuning of the Single Loop Controller PID loops is done via the Startup or Operate pages.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.5 Station Flow

The ControlWave Pump Controller will perform flow measurement in a variety of ways:

- If there is an analog flow transmitter available, the flow rate measurement and flow totalization will be performed via an analog input to the ControlWave Pump Controller.
- If there is a pulse type flow meter (turbine meter, ultrasonic meter, propeller meter) the flow rate measurement and flow totalization will be performed via a high speed counter input to the ControlWave Pump Controller.

- There are some flow meters that offer an analog variable for flow rate and a pulse signal for flow totalization. In this case, both an analog input and a high speed counter input would be used on the ControlWave Pump Controller.
- Finally, there are some systems where there is no flow measurement device at all, but flow can be estimated based on the run status of the pumps.

Configuration Wizard Select a Device

STATION FLOW	
Is there flow measured at this site?	Yes <input <="" td="" type="button" value="No?"/>
CONFIGURE FLOW INPUT	
Would you like to estimate flow based on pump run status at this site?	No Not Available
CONFIGURE ESTIMATED FLOW INPUT	
How is flow totalization performed?	PULSE <input <="" td="" type="button" value="Analog?"/>
CONFIGURE FLOW TOTALIZATION	

Bristol ControlWave Pump Station Controller **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

To configure the Flow Rate Input from an analog transmitter, click on **CONFIGURE FLOW INPUT** and see Section 3.5.1.

To configure Estimated Flow, Click on **ESTIMATE FLOW?** button, then click on **CONFIGURE ESTIMATED FLOW INPUT** and see Section 3.5.2.

To configure flow totalization, click on **CONFIGURE FLOW TOTALIZATION** and see Section 3.5.3.

3.5.1 Configure Flow Input

Configuration Wizard - Input Configuration

STATION FLOW		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
FLOW RATE	0.0	100.0	GPM	FLOW

BACK



Pump Station Controller

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
ZERO	The value of the flow rate variable at 4 mA or 1 volt.
SPAN	The difference between the value of the flow rate variable at 4 mA (or 1 volt) and its value at 20 mA (5 volts). For instance, if the ZERO is 0.0 GPM and the flow rate at 20 mA is 150.0 GPM, the SPAN is 150.0. If the ZERO is 15.0 GPM and the flow rate at 20 mA is 150.0 GPM, the SPAN is 135.0.
UNITS	The engineering units of the flow rate variable.
DESCRIPTOR	A textual description of the flow rate variable. This descriptor will be used throughout the rest of the menus to represent flow.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.5.2 Configure Estimated Flow Input

Configuration Wizard - Flow

ESTIMATED FLOW

Some users are able to estimate the flow based on the output of the pump(s). Each pump has a flow value associated with it. When a pump is running, the flow value associated with the pump is used to estimate the flow. When more than one pump is operating, station flow is determined by the sum of the estimated flow value for each pump.

	VALUE	PUMP 1	PUMP 2	PUMP 3	UNITS	DESCRIPTOR
FLOW	0.0	0.0	0.0	0.0	GPM	FLOW

BACK



Pump Station Controller



© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
VALUE	This is the live value of the estimated flow.
PUMP1, PUMP2, PUMP3	This is the estimated value of flow when each pump is running. If more than one pump is running, the estimated flow will be the sum of the estimated flow for each pump that is running.
UNITS	This is the engineering units for flow.
DESCRIPTOR	This is a textual description of the flow transmitter.

3.5.3 Configure Flow Totalization

Flow totalization can be performed one of two ways, by integrating the flow rate received via the analog input, or by accumulating pulses from a flow meter that represent a fixed volume of flow per pulse.

When totalization is performed using the analog input, the flow rate (Gallons per minute, gallons per hour, million gallons per day, etc.) is integrated to calculate the total volume (Gallons, Million Gallons, etc.) delivered over a period of time.

Configuration Wizard - Totalization

FLOW TOTALIZATION		
FLOW TOTALIZATION METHOD		
ANALOG	Pulse Counts?	
K FACTOR		VOLUME PER PULSE
TOTALIZER SPAN	1.000	

The totalizer span is used to adjust available flow rate units to desired flow total units. For instance, if the flow rate is in Gallons per Minute (GPM), and the desired flow total units are Million Gallons (MGals) the totalizer span is 0.00000001667.

$$\text{Total Span} = (\text{Gal/Min}) * (\text{Min}/60 \text{ Seconds}) * (\text{Seconds}/\text{Sample}) * (\text{MGals}/1,000,000 \text{ Gal})$$

$$\text{Total Span} = 1/(60 * 1,000,000)$$

$$\text{Total Span} = 0.00000001667$$

Other common conversions are:

Gallons Per Second (GPS) to Gals = 1.0
 Gallons Per Second (GPS) to MGals = 0.000001
 Gallons Per Minute (GPM) to Gals = 0.01667
 Gallons Per Minute (GPM) to MGals = 0.00000001667
 Gallons Per Hour (GPH) to Gals = 0.0002778
 Gallons Per Hour (GPH) to MGals = 0.0000000002778

BACK

In order to perform this integration, a totalizer span value must be entered. This totalizer span is used to adjust the available flow rate units to the desired flow total units.

For example, if the flow rate is in Gallons per Minute (GPM) and the desired flow total units are Million Gallons (MGals) the totalizer span is 0.00000001667, as shown by the calculation below:

TOTALIZER SPAN = (Gal/Minute) * (Minute/60 seconds) * (Seconds/Sample) * (MGals/1,000,000) GAL

TOTALIZER SPAN = 1/(60*1,000,000)

TOTALIZER SPAN = 0.00000001667

When totalization is performed using a pulse input, each pulse represents a fixed volume (Gallons, cubic feet, etc.) that has passed through the meter. In this case totalizing the volume requires that each pulse gets multiplied by a factor (commonly called a K Factor by the meter manufacturer). The K Factor must be entered as volume per pulse (for instance, 100 gallons/pulse).

However, some manufactures list their K Factor as pulses per volume (for instance, 11.7 pulses/gallon). In this case, the K Factor entered in the Pump Controller must be the reciprocal of the manufacturers K Factor.

In this example, our K Factor would be 1 Gallon/11.7 Pulses, or 0.08547 Gallons/Pulse.

In addition, the user may opt to adjust the totalized units using the K Factor. If the K Factor represents 1 gallon per pulse, but the user wanted to see total volume in Millions of Gallons (MGAL), the K Factor would be entered as 0.000001 (1/1,000,000).

Configuration Wizard - Totalization

FLOW TOTALIZATION

FLOW TOTALIZATION
METHOD

PULSE

Analog?

K FACTOR

1.000

VOLUME PER PULSE

TOTALIZER SPAN

The totalizer span is used to adjust available flow rate units to desired flow total units. For instance, if the flow rate is in Gallons per Minute (GPM), and the desired flow total units are Million Gallons (MGals) the totalizer span is 0.00000001667.

Total Span = (Gal/Min)*(Min/60 Seconds)*(Seconds/Sample)*(MGals/1,000,000 Gal)
Total Span = 1/(60*1,000,000)
Total Span = 0.00000001667

Other common conversions are:

Gallons Per Second (GPS) to Gals = 1.0
Gallons Per Second (GPS) to MGals = 0.000001
Gallons Per Minute (GPM) to Gals = 0.01667
Gallons Per Minute (GPM) to MGals = 0.00000001667
Gallons Per Hour (GPH) to Gals = 0.0002778
Gallons Per Hour (GPH) to MGals = 0.0000000002778

BACK

3.6 Alarm Limit Configuration

Selecting Alarm Limits from any analog configuration menu allows for configuration of the alarm limits for any and all analog input parameters.

Click here to configure alarm limits

Configuration Wizard - Input Configuration

STATION FLOW		ALARM LIMITS	
	ZERO	SPAN	UNITS
FLOW RATE	0.0	100.0	GPM

Alarm limits can be configured during the individual analog input configurations or after all inputs are configured.

ANALOG INPUT ALARM LIMITS				I/O CONFIG		
DEVICE	FLOW	SUCTION	DISCHARGE	CL2 RES	LEVEL	DRAWDOWN
VALUE	0.00	0.00	0.00	0.00	0.00	0.00
HI HI LIMIT	110.00	110.00	110.00	110.00	110.00	110.00
HIGH LIMIT	110.00	110.00	110.00	110.00	110.00	110.00
LOW LIMIT	-10.00	-10.00	-10.00	-10.00	-10.00	-10.00
LO LO LIMIT	-10.00	-10.00	-10.00	-10.00	-10.00	-10.00
HIGH DB	1.00	1.00	1.00	1.00	1.00	1.00
LOW DB	1.00	1.00	1.00	1.00	1.00	1.00
DAMPENING	ON	ON	ON	ON	ON	ON
DAMPENING TIME (Seconds)	4.00	4.00	4.00	4.00	4.00	4.00

ANALOG OUTPUT ALARM LIMITS		I/O CONFIG	
DEVICE	METERING PUMP		
VALUE	0.00		
HI HI LIMIT	110.00		

Alarm limits are provided for High, HI HI, Low, Low – Low. Each limit has an independent High and Low Deadband and dampening filter.

Field	Description
VALUE	The current value of this variable.
HI HI LIMIT	A high-high alarm message is generated when the variable's value exceeds this value. The high-high alarm condition remains in effect until the value of the variable falls below the HI HI LIMIT, minus the HIGH DB value.
HIGH LIMIT	A high alarm message is generated when the variable's value exceeds this value. The high alarm condition remains in effect until the value of the variable falls below the HIGH LIMIT, minus the HIGH DB value.
LOW LIMIT	A low alarm message is generated when the variable's value falls below this value. The low alarm condition remains in effect until the value of the variable rises above the LOW LIMIT, plus the LOW DB value.
LO LO LIMIT	A low-low alarm message is generated when the variable's value falls below this value. The low-low alarm condition remains in effect until the value of the variable rises above the LO LO LIMIT, plus the LOW DB value.
HIGH DB	A value used to define a range below the HI HI LIMIT, or HIGH LIMIT, within which the alarm condition for that limit still exists, even though the value of the variable is below the limit. This range helps reduce the number of multiple alarm and return-to normal messages being generated if the value of the variable is fluctuating near the alarm limit.
LOW DB	A value used to define a range above the HI HI LIMIT, or HIGH LIMIT, within which the alarm condition for that limit still exists, even though the value of the variable is above the limit. This range helps reduce the number of multiple alarm and return-to normal messages being generated if the value of the variable is fluctuating near the alarm limit.
DAMPENING	When ON, enables the dampening feature. When OFF, the dampening feature is disabled. The dampening feature delays the speed of the response of the output to a given change of the input. It is used to slow down the output response to a rapid or oscillatory change of the measured variable.
DAMPENING TIME (seconds)	The period of time (in seconds) during which the indicated value changes only 63% of the difference between the 'present measured variable' and the 'present indicated value' in one damping time period. It would take 5 times the Dampening Time for the 'present indicated pressure' to equal the 'present measured pressure' (if a change in the 'present measured pressure' didn't occur). An increase in the Dampening Time results in an increased smoothing of the indicated value.

3.7 Discharge Pressure Measurement and Control

The ControlWave Pump Controller will perform discharge pressure measurement.

Configuration Wizard Select a Device Configure

DISCHARGE PRESSURE		
Is there a local discharge or system pressure used at this site?	Yes	No?
	CONFIGURE DISCHARGE PRESSURE INPUT	
Is the discharge or system pressure used for primary control of local pumps at this site?	Yes	No?
	CONFIGURE DISCHARGE PRESSURE CONTROL	
Is the discharge or system pressure used for override control of the local pumps?	Yes	No?
	CONFIGURE DISCHARGE PRESSURE OVERRIDE	

BACK NEXT FINISH

Bristol ControlWave **Pump Station Controller** **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

In addition, the discharge pressure may be used for primary control of the pumps, or override control of the pumps.

To configure the Discharge Pressure Input from an analog transmitter, click on CONFIGURE DISCHARGE PRESSURE INPUT and see Section 3.7.1

To configure the discharge pressure for primary pump control, click on CONFIGURE DISCHARGE PRESSURE CONTROL and see Section 3.7.2

To configure the discharge pressure for override pump control, click on CONFIGURE DISCHARGE PRESSURE OVERRIDE and see Section 3.7.3

3.7.1 Configure Discharge Pressure Input

Configuration Wizard - Input Configuration

DISCHARGE PRESSURE		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
PRESSURE	0.0	100.0	PSI	DISCHARGE

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
ZERO	The value of the discharge pressure value when the analog input is at 4 mA or 1 volt.
SPAN	Enter the SPAN value. The SPAN represents the difference between the discharge pressure value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 PSI and the discharge pressure at 20 mA is 300.0 PSI, the SPAN is 300.0. If the ZERO is 25.0 PSI and the discharge pressure at 20 mA is 300.0 GPM, the SPAN is 275.0.
UNITS	The engineering units of the discharge pressure input.
DESCRIPTOR	A textual description of the discharge pressure input. This descriptor will be used throughout the rest of the menus to represent discharge pressure.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.7.2 Configure Discharge Pressure Control

Configuration Wizard - Control Configuration

PUMPS AVAILABLE	3			
DISCHARGE PRESSURE CONTROL				
DISCHARGE	0.0 PSI			
PUMP	START SETPOINT	STOP SETPOINT	START COMMAND	STOP COMMAND
LEAD	0.0	0.0	OFF	OFF
LAG 1	0.0	0.0	OFF	OFF
LAG 2	0.0	0.0	OFF	OFF

BACK

 **Pump Station Controller** 

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
PUMPS AVAILABLE	This represents the number of pumps available for control.
DISCHARGE (or other name)	This is the DESCRIPTOR assigned to the Discharge Pressure Input. The field to the right is the live Discharge Pressure reading.
LEAD / LAG1 / LAG2 START SETPOINT	When the live pressure value drops below this setpoint, the appropriate pump START COMMAND will be set to START.
LEAD / LAG1 / LAG2 STOP SETPOINT	When the live pressure value rises above this setpoint, the appropriate pump STOP COMMAND will be set to STOP.
LEAD / LAG1 / LAG2 START COMMAND	When the live pressure value drops below the START SETPOINT, the corresponding START COMMAND is set to START, to start the pump. Otherwise, it is set to OFF.
LEAD / LAG1 / LAG2 STOP COMMAND	When the live pressure value rises above the STOP SETPOINT, the corresponding STOP COMMAND is set to STOP, to stop the pump. Otherwise, it is set to OFF.

To configure alarm limits, click on **ALARM LIMITS**. (See Section 3.6 for details.)

When finished, click on **BACK**.

3.7.3 Configure Discharge Pressure Override Control

Configuration Wizard - Override Control

DISCHARGE PRESSURE OVERRIDE CONTROL					
	0.00 PSI			SETPOINT	COMMAND
DISABL	START OVERRIDE	ONLOW	DISCHARGE	0.00	OFF
DISABL	STOP OVERRIDE	ONLOW		0.00	OFF
STOP OVERRIDE WILL BE		PERMIS			

BACK



Pump Station Controller

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Override Control provides start and stop overrides that would take precedence over primary control. Override Control is used to either start a single pump or stop all pumps.

From here, either or both START OVERRIDE control and STOP OVERRIDE control can be enabled and configured.

Field	Description
START OVERRIDE	<i>Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu.</i>
ENABLE/DISABL	When enabled, a pump can be started based on whether the discharge pressure value either exceeds (ONHIGH) or falls below (ONLOW) the START OVERRIDE SETPOINT. This start command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
START OVERRIDE	<i>Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.</i>
ONLOW / ONHIGH	When START OVERRIDE is enabled, 'ONLOW' causes the START OVERRIDE command to be activated when the discharge pressure value falls below the START OVERRIDE SETPOINT. When START OVERRIDE is enabled, 'ONHIGH' causes the START OVERRIDE command to be activated when the discharge pressure value rises above the START

	Override SETPOINT. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE SETPOINT	When START OVERRIDE is enabled, this is the trigger value for the discharge pressure at which a pump will be started. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE COMMAND	Displays 'START' when the START OVERRIDE condition exists or 'OFF' when the START OVERRIDE condition does not exist.
STOP OVERRIDE ENABLE/DISABLE	Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu. When enabled, a pump can be stopped based on whether the discharge pressure value either exceeds (ONHIGH) or falls below (ONLOW) the STOP OVERRIDE SETPOINT. This stop command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
STOP OVERRIDE ONLOW / ONHIGH	Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu. When STOP OVERRIDE is enabled, 'ONLOW' causes the STOP OVERRIDE command to be activated when the discharge pressure value falls below the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is enabled, 'ONHIGH' causes the STOP OVERRIDE command to be activated when the discharge pressure value rises above the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE SETPOINT	When STOP OVERRIDE is enabled, this is the trigger value for the discharge pressure at which a pump will be stopped. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE COMMAND	Displays 'STOP' when the STOP OVERRIDE condition exists or 'OFF' when the STOP OVERRIDE condition does not exist.
STOP OVERRIDE WILL BE PERMIS INTLCK	The user can choose whether the STOP OVERRIDE is a PERMISSIVE OVERRIDE (PERMIS) or an INTERLOCKED OVERRIDE (INTLCK). A PERMISSIVE STOP OVERRIDE may be overridden by a START OVERRIDE, but will not be overridden by a start command issued by any of the primary controls. An INTERLOCKED STOP OVERRIDE will not be overridden by any start command, whether issued by a primary control or an override control.

When finished, click on BACK.

3.8 Suction Pressure Measurement and Control

The ControlWave Pump Controller will perform suction pressure measurement.

In addition, the suction pressure may be used for override control of the pumps.

To configure the Suction Pressure Input from an analog transmitter, click on **CONFIGURE SUCTION PRESSURE INPUT** and see Section 3.8.1.

To configure the suction pressure for override pump control, click on **CONFIGURE SUCTION PRESSURE OVERRIDE** and see Section 3.8.2.

3.8.1 Configure Suction Pressure Input

Configuration Wizard - Input Configuration

SUCTION PRESSURE		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
PRESSURE	0.0	100.0	UNITS	XMTR_DESC

BACK

Bristol ControlWave Pump Station Controller **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
ZERO	The value of the suction pressure value when the analog input is at 4 mA or 1 volt.
SPAN	Enter the SPAN value. The SPAN represents the difference between the suction pressure value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 PSI and the suction pressure at 20 mA is 300.0 PSI, the SPAN is 300.0. If the ZERO is 25.0 PSI and the suction pressure at 20 mA is 300.0 GPM, the SPAN is 275.0.
UNITS	The engineering units of the suction pressure input.
DESCRIPTOR	A textual description of the suction pressure input. This descriptor will be used throughout the rest of the menus to represent suction pressure.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.8.2 Configure Suction Pressure Override

Configuration Wizard - Override Control

SUCTION PRESSURE OVERRIDE CONTROL					
	0.00 PSI			SETPOINT	COMMAND
DISABL	START OVERRIDE	ONLOW		0.00	OFF
ENABLE	STOP OVERRIDE	ONLOW	SUCTION	0.00	OFF
STOP OVERRIDE WILL BE		INTLCK			

BACK

Bristol

ControlWave

Pump Station Controller

EMERSON

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Override Control provides start and stop overrides that would take precedence over primary control. Override Control is used to either start a single pump or stop all pumps.

From here, either or both START OVERRIDE control and STOP OVERRIDE control can be enabled and configured.

Field	Description
START OVERRIDE	Typically, START OVERRIDE would not be used with suction pressure, however, it is supported if required.
ENABLE/DISABL	Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu. When enabled, a pump can be started based on whether the suction pressure value either exceeds (ONHIGH) or falls below (ONLOW) the START OVERRIDE SETPOINT. This start command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
START OVERRIDE	Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.
ONLOW / ONHIGH	When START OVERRIDE is enabled, 'ONLOW' causes the START OVERRIDE command to be activated when the suction pressure value falls below the START

	OVERRIDE SETPOINT. When START OVERRIDE is enabled, 'ONHIGH' causes the START OVERRIDE command to be activated when the suction pressure value rises above the START OVERRIDE SETPOINT. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE SETPOINT	When START OVERRIDE is enabled, this is the trigger value for the suction pressure at which a pump will be started. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE COMMAND	Displays 'START' when the START OVERRIDE condition exists or 'OFF' when the START OVERRIDE condition does not exist.
STOP OVERRIDE ENABLE/DISABLE	Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu. When enabled, a pump can be stopped based on whether the suction pressure value either exceeds (ONHIGH) or falls below (ONLOW) the STOP OVERRIDE SETPOINT. This stop command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
STOP OVERRIDE ONLOW / ONHIGH	It is very common to use low suction pressure for STOP OVERRIDE. Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu. When STOP OVERRIDE is enabled, 'ONLOW' causes the STOP OVERRIDE command to be activated when the suction pressure value falls below the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is enabled, 'ONHIGH' causes the STOP OVERRIDE command to be activated when the suction pressure value rises above the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE SETPOINT	When STOP OVERRIDE is enabled, this is the trigger value for the suction pressure at which a pump will be stopped. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE COMMAND	Displays 'STOP' when the STOP OVERRIDE condition exists or 'OFF' when the STOP OVERRIDE condition does not exist.
STOP OVERRIDE WILL BE PERMISS / INTLCK	The user can choose whether the STOP OVERRIDE is a PERMISSIVE OVERRIDE (PERMIS) or an INTERLOCKED OVERRIDE (INTLCK). A PERMISSIVE STOP OVERRIDE may be overridden by a START OVERRIDE, but will not be overridden by a start command issued by any of the primary controls. An INTERLOCKED STOP OVERRIDE will not be overridden

by any start command, whether issued by a primary control or an override control.

When finished, click on BACK.

3.9 Local Tank Level Measurement and Control

The ControlWave Pump Controller will perform local tank level measurement.

Configuration Wizard Select a Device Configure

LOCAL TANK		
Is there a local level (tank, reservoir, wetwell, clearwell) included at this site?	Yes	No?
CONFIGURE LEVEL INPUT		
Is the local level used for primary control of local pumps at this site?	Yes	No?
CONFIGURE LEVEL CONTROL		
Are the local pumps used to fill (pump up) or empty (pump down) the local tank at this site?	PUMPUP	Pump Down?
Is the local level used for override control of the local pumps?	Yes	No?
CONFIGURE LEVEL OVERRIDE		
Are there floats in the local tank used to control the local pumps?	Yes	No?
Do the floats cause the pump to fill (pump up) or empty (pump down) the local tank at this site?	PUMPUP	Pump Down?

BACK **NEXT** **FINISH**

Bristol ControlWave Pump Station Controller **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

The local tank level can be used for primary and override control.

In addition, float switches can be used to perform pump control, either as primary or backup control to the tank level transmitter. If using float switches in the local tank, select whether the floats are used for PUMP UP or PUMP DOWN control.

To configure the local tank level input from an analog transmitter, click on CONFIGURE LEVEL INPUT and see Section 3.9.1

To configure the local tank level for primary pump control, first select whether operating the pumps will fill the tank (PUMP UP control) or operating the pumps will empty the tank (PUMP DOWN control). After selecting PUMP UP or PUMP DOWN control, click on CONFIGURE LEVEL CONTROL and see Section 3.9.2.

To configure the local tank level for override pump control, click on CONFIGURE LEVEL OVERRIDE and see Section 3.9.3.

3.9.1 Configure Level Input

Configuration Wizard - Input Configuration

LOCAL LEVEL		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
LEVEL	0.0	100.0	FEET	CLEARWELL
VOLUME	0.0	100.0	MGAL	CLEARWELLVOLUME

BACK

 **Pump Station Controller** 

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
LEVEL ZERO	Enter the ZERO value. This represents the level value when the analog input is at 4 mA or 1 Volt).
LEVEL SPAN	Enter the SPAN value. The SPAN represents the difference between the level value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 FEET and the level at 20 mA is 35.0 FEET, the SPAN is 35.0. If the ZERO is 35.0 FEET and the level at 20 mA is 45.0 FEET, the SPAN is 10.0.
LEVEL UNITS	Enter the engineering units indicating level.

LEVEL DESCRIPTOR	Enter a descriptor for the local level transmitter. This descriptor will be used throughout the rest of the menus to represent local level.
-----------------------------	---

In addition to the level, it is possible in some cases to calculate the volume in the tank. This is only possible when there is a linear relationship between level and volume. In other words, if 1 foot of tank level always equals the same number of gallons in the tank, then volume can be calculated. However, if the tank is non-linear (for instance, a tank shaped like a sphere or a cylinder lying horizontally) volume measurement is not possible.

VOLUME ZERO	Enter the ZERO value. This represents the volume value when the level value is at zero.
VOLUME SPAN	Enter the SPAN value. The SPAN represents the difference between the volume value when the level input is at 20 mA or 5 Volts and when the level input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 GALLONS and the volume when the level input at 20 mA is 300,000 GALLONS, the SPAN is 300,000.0. If the ZERO is 10,000.0 GALLONS and the volume when the level input is at 20 mA is 50,000 GALLONS, the SPAN is 40,000.0.
VOLUME UNITS	Enter the engineering units indicating volume.
VOLUME DESCRIPTOR	The volume descriptor will be generated automatically by appending the word 'VOLUME' to the LEVEL DESCRIPTOR. This descriptor will be used throughout the rest of the menus to represent volume of the local tank.

To configure alarm limits, click on **ALARM LIMITS**. (See Section 3.6 for details.)

When finished, click on **BACK**.

3.9.2 Configure Level Control

Configuration Wizard - Control Configuration

PUMPS AVAILABLE	3			
LOCAL LEVEL CONTROL				
CLEARWELL	0.0	FEET		
PUMP	START SETPOINT	STOP SETPOINT	START COMMAND	STOP COMMAND
LEAD	0.0	0.0	OFF	OFF
LAG 1	0.0	0.0	OFF	OFF
LAG 2	0.0	0.0	OFF	OFF

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
PUMPS AVAILABLE	The number of pumps available for control.
Descriptor	This is the descriptor for the Local Level Input. By default, this shows 'CLEARWELL'.
Level Reading	The live, local level reading.
LEAD, LAG1/2 START SETPOINT & START COMMAND	Setting the START SETPOINTS depends on whether PUMP UP control or PUMP DOWN control was selected. When PUMP UP control is selected, if the live tank level drops below the START SETPOINT, the appropriate pump START COMMAND will be set to START. When PUMP DOWN control is selected, if the live tank level rises above the START SETPOINT, the appropriate pump START COMMAND will be set to START.
LEAD, LAG1/2 STOP SETPOINT & STOP COMMAND	Setting the STOP SETPOINTS depends on whether PUMP UP control or PUMP DOWN control was selected. When PUMP UP control is selected, if the live tank level

When the live tank level rises above the STOP SETPOINT, the appropriate pump STOP COMMAND will be set to STOP.

When PUMP DOWN control is selected, if the live tank level falls below the STOP SETPOINT, the appropriate pump STOP COMMAND will be set to STOP.

When finished, click on BACK.

3.9.3 Configure Level Override

Override Control provides start and stop overrides that would take precedence over primary control. Override Control is used to either start a single pump or stop all pumps.

From here, either or both START OVERRIDE control and STOP OVERRIDE control can be enabled and configured.

Configuration Wizard - Override Control

LEVEL OVERRIDE CONTROL				SETPOINT	COMMAND
DISABL	START OVERRIDE	ONLOW	CLEARWELL	0.00	OFF
DISABL	STOP OVERRIDE	ONLOW		0.00	OFF
STOP OVERRIDE WILL BE		PERMIS			

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
START OVERRIDE	Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu.

ENABLE/DISABLE	When enabled, a pump can be started based on whether the local tank level value either exceeds (ONHIGH) or falls below (ONLOW) the START OVERRIDE SETPOINT. This start command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
START OVERRIDE	<i>Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.</i>
ONLOW / ONHIGH	When START OVERRIDE is enabled, 'ONLOW' causes the START OVERRIDE command to be activated when the local tank level value falls below the START OVERRIDE SETPOINT. When START OVERRIDE is enabled, 'ONHIGH' causes the START OVERRIDE command to be activated when the local tank level value rises above the START OVERRIDE SETPOINT. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE SETPOINT	When START OVERRIDE is enabled, this is the trigger value for the local tank level at which a pump will be started. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE COMMAND	Displays 'START' when the START OVERRIDE condition exists or 'OFF' when the START OVERRIDE condition does not exist.
STOP OVERRIDE ENABLE/DISABLE	<i>Right-click in this field, and choose either 'ENABLE' or 'DISABLE' from the drop-down menu.</i> When enabled, a pump can be stopped based on whether the local tank level value either exceeds (ONHIGH) or falls below (ONLOW) the STOP OVERRIDE SETPOINT. This stop command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
STOP OVERRIDE ONLOW / ONHIGH	<i>Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.</i> When STOP OVERRIDE is enabled, 'ONLOW' causes the STOP OVERRIDE command to be activated when the local tank level value falls below the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is enabled, 'ONHIGH' causes the STOP OVERRIDE command to be activated when the local tank level value rises above the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE SETPOINT	When STOP OVERRIDE is enabled, this is the trigger value for the local tank level at which a pump will be stopped. When STOP OVERRIDE is disabled, this field is ignored.

STOP OVERRIDE COMMAND	Displays 'STOP' when the STOP OVERRIDE condition exists or 'OFF' when the STOP OVERRIDE condition does not exist.
STOP OVERRIDE WILL BE PERMISSIVE / INTLCK	The user can choose whether the STOP OVERRIDE is a PERMISSIVE OVERRIDE (PERMIS) or an INTERLOCKED OVERRIDE (INTLCK). A PERMISSIVE STOP OVERRIDE may be overridden by a START OVERRIDE, but will not be overridden by a start command issued by any of the primary controls. An INTERLOCKED STOP OVERRIDE will not be overridden by any start command, whether issued by a primary control or an override control.

When finished, click on BACK.

3.10 Remote Tank Level Measurement and Control

The ControlWave Pump Controller will perform remote tank level measurement.

The remote tank level is identical to the local tank level indication, with the following exceptions:

- There are no provisions for float control when using a remote tank level.
- There are no volume calculations provided for the remote tank level.

Configuration Wizard [Select a Device] [Configure]

REMOTE TANK	
Is there a remote level (tank, reservoir, wetwell, clearwell) used at this site?	Yes No?
CONFIGURE LEVEL INPUT	
Is the remote level used for primary control of local pumps at this site?	Yes No?
CONFIGURE LEVEL CONTROL	
Are the local pumps used to fill (pump up) or empty (pump down) the remote tank?	PUMPUP Pump Down?
Is the remote level used for override control of the local pumps?	Yes No?
CONFIGURE LEVEL OVERRIDE	

BACK NEXT FINISH

Bristol ControlWave Pump Station Controller EMERSON

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

To configure the remote tank level input, click on **CONFIGURE LEVEL INPUT** and refer to Section 3.10.1.

To configure the remote tank level for primary pump control, first select whether operating the pumps will fill the tank (**PUMP UP** control) or operating the pumps will empty the tank (**PUMP DOWN** control). After selecting **PUMP UP** or **PUMP DOWN** control, click on **CONFIGURE LEVEL CONTROL** and refer to Section 3.10.2.

To configure the level override, click on **CONFIGURE LEVEL OVERRIDE** and refer to Section 3.10.3.

3.10.1 Configure Level Input

Configuration Wizard - Input Configuration

REMOTE LEVEL	ALARM LIMITS			
	ZERO	SPAN	UNITS	DESCRIPTOR
LEVEL	0.0	100.0	UNITS	XMTR_DESC

BACK



Pump Station Controller



© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
LEVEL ZERO	Enter the ZERO value. This represents the level value when the analog input is at 4 mA or 1 Volt).
LEVEL SPAN	Enter the SPAN value. The SPAN represents the difference between the level value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 FEET and the level at 20 mA is 35.0 FEET, the SPAN is 35.0. If the ZERO is 35.0 FEET and the level at 20 mA is 45.0 FEET, the SPAN is 10.0.

LEVEL UNITS	Enter the engineering units indicating level.
LEVEL DESCRIPTOR	Enter a descriptor for the remote level transmitter. This descriptor will be used throughout the rest of the menus to represent local level.

To configure alarm limits, click on **ALARM LIMITS**. (See Section 3.6 for details.)

When finished, click on **BACK**.

3.10.2 Configure Level Control

Configuration Wizard - Control Configuration

PUMPS AVAILABLE	3			
REMOTE LEVEL CONTROL				
XMTR_DESC	0.0	UNITS		
PUMP	START SETPOINT	STOP SETPOINT	START COMMAND	STOP COMMAND
LEAD	0.0	0.0	OFF	OFF
LAG 1	0.0	0.0	OFF	OFF
LAG 2	0.0	0.0	OFF	OFF

BACK



Pump Station Controller



© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
PUMPS AVAILABLE	The number of pumps available for control.
Descriptor	This is the descriptor for the Remote Level Input. By default, this shows 'XMTR_DESC'.
Level Reading	The live, local level reading.

LEAD, LAG1/2 START SETPOINT & START COMMAND	Setting the START SETPOINTS depends on whether PUMP UP control or PUMP DOWN control was selected. When PUMP UP control is selected, if the live tank level drops below the START SETPOINT, the appropriate pump START COMMAND will be set to START. When PUMP DOWN control is selected, if the live tank level rises above the START SETPOINT, the appropriate pump START COMMAND will be set to START.
LEAD, LAG1/2 STOP SETPOINT & STOP COMMAND	Setting the STOP SETPOINTS depends on whether PUMP UP control or PUMP DOWN control was selected. When PUMP UP control is selected, if the live tank level rises above the STOP SETPOINT, the appropriate pump STOP COMMAND will be set to STOP. When PUMP DOWN control is selected, if the live tank level falls below the STOP SETPOINT, the appropriate pump STOP COMMAND will be set to STOP.

When finished, click on BACK.

3.10.3 Configure Level Override

Configuration Wizard - Override Control

REMOTE LEVEL OVERRIDE CONTROL					
			0.00 UNITS	SETPOINT	COMMAND
DISABL	START OVERRIDE	ONLOW		0.00	OFF
DISABL	STOP OVERRIDE	ONLOW	XMTR_DESC	0.00	OFF
STOP OVERRIDE WILL BE		PERMIS			

BACK



Pump Station Controller



© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
START OVERRIDE	<i>Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu.</i>
ENABLE/DISABL	When enabled, a pump can be started based on whether the remote tank level value either exceeds (ONHIGH) or falls below (ONLOW) the START OVERRIDE SETPOINT. This start command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
START OVERRIDE	<i>Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.</i>
ONLOW / ONHIGH	When START OVERRIDE is enabled, 'ONLOW' causes the START OVERRIDE command to be activated when the local tank level value falls below the START OVERRIDE SETPOINT. When START OVERRIDE is enabled, 'ONHIGH' causes the START OVERRIDE command to be activated when the remote tank level value rises above the START OVERRIDE SETPOINT. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE SETPOINT	When START OVERRIDE is enabled, this is the trigger value for the remote tank level at which a pump will be started. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE COMMAND	Displays 'START' when the START OVERRIDE condition exists or 'OFF' when the START OVERRIDE condition does not exist.
STOP OVERRIDE	<i>Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu.</i>
ENABLE/DISABLE	When enabled, a pump can be stopped based on whether the remote tank level value either exceeds (ONHIGH) or falls below (ONLOW) the STOP OVERRIDE SETPOINT. This stop command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
STOP OVERRIDE	<i>Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.</i>
ONLOW / ONHIGH	When STOP OVERRIDE is enabled, 'ONLOW' causes the STOP OVERRIDE command to be activated when the remote tank level value falls below the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is enabled, 'ONHIGH' causes the STOP OVERRIDE command to be activated when the remote tank level value rises above the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is disabled, this field is ignored.

STOP OVERRIDE SETPOINT	When STOP OVERRIDE is enabled, this is the trigger value for the remote tank level at which a pump will be stopped. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE COMMAND	Displays 'STOP' when the STOP OVERRIDE condition exists or 'OFF' when the STOP OVERRIDE condition does not exist.
STOP OVERRIDE WILL BE PERMISSIVE / INTLCK	The user can choose whether the STOP OVERRIDE is a PERMISSIVE OVERRIDE (PERMIS) or an INTERLOCKED OVERRIDE (INTLCK). A PERMISSIVE STOP OVERRIDE may be overridden by a START OVERRIDE, but will not be overridden by a start command issued by any of the primary controls. An INTERLOCKED STOP OVERRIDE will not be overridden by any start command, whether issued by a primary control or an override control.

When finished, click on BACK.

3.11 Well Drawdown Level Measurement and Control

The ControlWave Pump Controller will perform well drawdown level measurement.

In addition, the well drawdown level may be used for override control of the pumps.

For details on configuring the well drawdown level input, refer to Section 3.11.1.

For details on configuring the well drawdown override control, refer to the Section 3.11.2.

3.11.1 Configure Well Drawdown Level Input

Configuration Wizard - Input Configuration

WELL DRAWDOWN		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
LEVEL	0.0	100.0	UNITS	XMTR_DESC

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
LEVEL ZERO	Enter the ZERO value. This represents the level value when the analog input is at 4 mA or 1 Volt).
LEVEL SPAN	Enter the SPAN value. The SPAN represents the difference between the level value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 FEET and the level at 20 mA is 35.0 FEET, the SPAN is 35.0. If the ZERO is 35.0 FEET and the level at 20 mA is 45.0 FEET, the SPAN is 10.0.
LEVEL UNITS	Enter the engineering units indicating level.
LEVEL DESCRIPTOR	Enter a descriptor for the well drawdown level transmitter. This descriptor will be used throughout the rest of the menus to represent local level.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.11.2 Configure Well Drawdown Level Override

Configuration Wizard - Override Control

WELL DRAWDOWN LEVEL OVERRIDE CONTROL

	0.00	UNITS		SETPOINT	COMMAND
DISABL	START OVERRIDE	ONLOW	XMTR_DESC	0.00	OFF
DISABL	STOP OVERRIDE	ONLOW		0.00	OFF
STOP OVERRIDE WILL BE		PERMIS			

BACK

Bristol

ControlWave

Pump Station Controller

EMERSON

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Override Control provides start and stop overrides that would take precedence over primary control. Override Control is used to either start a single pump or stop all pumps.

From here, either or both START OVERRIDE control and STOP OVERRIDE control can be enabled and configured.

Field	Description
START OVERRIDE	Right-click in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu.
ENABLE/DISABL	When enabled, a pump can be started based on whether the drawdown level value either exceeds (ONHIGH) or falls below (ONLOW) the START OVERRIDE SETPOINT. This start command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
START OVERRIDE	Right-click in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu.
ONLOW / ONHIGH	When START OVERRIDE is enabled, 'ONLOW' causes the START OVERRIDE command to be activated when the drawdown level value falls below the START OVERRIDE SETPOINT. When START OVERRIDE is enabled, 'ONHIGH' causes the START OVERRIDE command to be activated when the drawdown level value rises above the START

3-42

Configuration

Issued Oct-08

	OVERRIDE SETPOINT. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE SETPOINT	When START OVERRIDE is enabled, this is the trigger value for the drawdown level at which a pump will be started. When START OVERRIDE is disabled, this field is ignored.
START OVERRIDE COMMAND	Displays 'START' when the START OVERRIDE condition exists or 'OFF' when the START OVERRIDE condition does not exist.
STOP OVERRIDE ENABLE/DISABLE	<i>Right-click</i> in this field, and choose either 'ENABLE' or 'DISABL' from the drop-down menu. When enabled, a pump can be stopped based on whether the drawdown level value either exceeds (ONHIGH) or falls below (ONLOW) the STOP OVERRIDE SETPOINT. This stop command takes precedence over the primary pump control scheme. When disabled, the pump is only under primary control.
STOP OVERRIDE ONLOW / ONHIGH	It is very common to use low suction pressure for STOP OVERRIDE. <i>Right-click</i> in this field, and choose either 'ONLOW' or 'ONHIGH' from the drop-down menu. When STOP OVERRIDE is enabled, 'ONLOW' causes the STOP OVERRIDE command to be activated when the drawdown level value falls below the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is enabled, 'ONHIGH' causes the STOP OVERRIDE command to be activated when the drawdown level value rises above the STOP OVERRIDE SETPOINT. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE SETPOINT	When STOP OVERRIDE is enabled, this is the trigger value for the drawdown level at which a pump will be stopped. When STOP OVERRIDE is disabled, this field is ignored.
STOP OVERRIDE COMMAND	Displays 'STOP' when the STOP OVERRIDE condition exists or 'OFF' when the STOP OVERRIDE condition does not exist.
STOP OVERRIDE WILL BE PERMIS INTLCK	The user can choose whether the STOP OVERRIDE is a PERMISSIVE OVERRIDE (PERMIS) or an INTERLOCKED OVERRIDE (INTLCK). A PERMISSIVE STOP OVERRIDE may be overridden by a START OVERRIDE, but will not be overridden by a start command issued by any of the primary controls. An INTERLOCKED STOP OVERRIDE will not be overridden by any start command, whether issued by a primary control or an override control.

When finished, click on BACK.

3.12 Time Control

The ControlWave Pump Controller will perform pump control based on the time of day.

The screenshot shows the 'Configuration Wizard' interface for the 'Pump Station Controller'. At the top, there is a 'Select a Device' dropdown menu and a 'Configure' button. The main section is titled 'TIME CONTROL' and contains two questions with 'Yes' and 'No?' buttons. The first question is 'Are the pumps at this site primarily controlled based on the time of day?' with a green 'Yes' button and a yellow 'No?' button. Below the 'Yes' button is a blue button labeled 'CONFIGURE TIMECLOCK CONTROL'. The second question is 'Are there any times during the day when all pumps at this site should be prevented from running? This is an override control function that applies to all pumps.' with a green 'Yes' button and a yellow 'No?' button. Below the 'Yes' button is a blue button labeled 'CONFIGURE RESTRICTED TIME OF USE OVERRIDE'. At the bottom of the wizard, there are three buttons: 'BACK', 'NEXT', and 'FINISH'. The footer includes the Bristol ControlWave logo, the text 'Pump Station Controller', the Emerson logo, and a copyright notice: '© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.'

TIME CONTROL	
Are the pumps at this site primarily controlled based on the time of day?	Yes No? CONFIGURE TIMECLOCK CONTROL
Are there any times during the day when all pumps at this site should be prevented from running? This is an override control function that applies to all pumps.	Yes No? CONFIGURE RESTRICTED TIME OF USE OVERRIDE

BACK NEXT FINISH

Bristol ControlWave **Pump Station Controller** **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

There is timeclock control, for starting and stopping pumps at a specific time each day. To configure the time clock for primary pump control, click on CONFIGURE TIMECLOCK CONTROL and see Section 3.12.1.

There is also a restricted time-of-use override control, used to prevent pumps from operating during specific hours during the day. To configure the restricted time-of-use feature, click on CONFIGURE RESTRICTED TIME OF USE OVERRIDE and see Section 3.12.2.

3.12.1 Configure Timeclock Control

Configuration Wizard - Control Configuration

TIMECLOCK CONTROL CONFIGURATION			
Time of Day	7/30/2007 22:48:36		Command
Pumps Available	3		
Pump	No Selection	LEAD	OFF
Refresh	Read from Array	LAG 1	OFF
Update	Write to Array	LAG 2	OFF
Time		Command Setting	
0000 - 0059	Start?	FALSE	
0100 - 0159	Start?	FALSE	
0200 - 0259	Start?	FALSE	
0300 - 0359	Start?	FALSE	
0400 - 0459	Start?	FALSE	
0500 - 0559	Start?	FALSE	
0600 - 0659	Start?	FALSE	
0700 - 0759	Start?	FALSE	
0800 - 0859	Start?	FALSE	
0900 - 0959	Start?	FALSE	
1000 - 1059	Start?	FALSE	
1100 - 1159	Start?	FALSE	
1200 - 1259	Start?	FALSE	
1300 - 1359	Start?	FALSE	
1400 - 1459	Start?	FALSE	
1500 - 1559	Start?	FALSE	

Field	Description
Time of Day	This represents the date and time from the real-time clock resident on the ControlWave Pump Controller. NOTE – this time may be different from the time on the PC.
Pumps Available	This represents the number of pumps available for control.
Pump	Select the pump to be configured by right clicking in the field and selecting LEAD, LAG 1, or LAG 2.
Refresh	Clicking on READ FROM ARRAY reloads data to the screen from the ControlWave Pump Controller, to show the current timeclock configuration for the pump selected. This action must be performed whenever the pump selection is changed, in order to see the current configuration of the pump.

Update	Clicking on WRITE TO ARRAY will download the current timeclock settings from the screen to the configuration for the selected pump.
Lead/Lag1/Lag2 Command	These fields represent the current state of the START command being issued by the timeclock control for each of the pumps. NOTE – When the timeclock START command transitions from START to OFF, a STOP command is issued for five (5) seconds. This will stop the appropriate pump, and this pump will not be restarted until another start command is issued by the program. The new start command may come from any source (discharge pressure, tank level, etc.)

Configuring the Timeclock:

To configure the timeclock, follow these steps:

1. Select the pump to be configured by right clicking on the PUMP field and selecting LEAD, LAG 1 or LAG 2 (as appropriate).
2. Click on REFRESH. This will allow the current settings for the selected pump to be reviewed before making changes.
3. To configure a pump to run during a particular hour, click on the START? button for that hour. (*If the specific hour is not visible, use the scroll bar to bring it into view.*). Once you have clicked on the appropriate START? Button, the field to the right should change from FALSE to START. If the field already indicates START, the pump is configured to run during that hour.
4. In order to set the timeclock control command for a specific hour to FALSE, click on the OFF? button. The field to the right should change from START to FALSE.
5. When the configuration settings are complete, click on the UPDATE button. The configuration for the pump selected will now be saved to the ControlWave Pump Controller.

Note: If the COMMAND SETTING field for a particular hour is false, other control parameters (tank level, discharge pressure, etc.) can cause the pump to start. The timeclock is not used to prevent a pump from running. To prevent a pump from being started during a particular time of day, the RESTRICTED TIME OF USE function must be used.

When finished, click on BACK.

3.12.2 Configure Restricted Time of Use Override

Configuration Wizard - Override Control

RESTRICTED TIME-OF-USE CONFIGURATION		
Time of Day	7/30/2007 22:49:20	
	Start Hour (0-23)	End Hour (0-23)
Restricted TOU Period 1	0	0
Restricted TOU Period 2	0	0
Permissive Command	PERMIS	
	Disable?	Enabled

The Restricted Time-of-Use (TOU) function is used to prevent a device from operating during certain times of the day. It is typically used to prevent operation of pumps during peak energy usage periods.

During the restricted TOU periods, operation of all pumps at the site will be prohibited (the permissive command will be set to OFF).

Outside of the restricted TOU periods, pump operation will not be affected by the TOU logic (the permissive command will be set to PERMIS).

BACK

 **Pump Station Controller** 

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Note: The restricted Time-Of-Use (TOU) override is a permissive override. This means that if there is a start override configured (for instance, a start override on extremely low tank level or system pressure), a pump will be started, even during the restricted time-of-use period.

When enabled, the user can set two periods to restrict operation of all pumps. This is typically used to prevent pumps from operating during periods of high energy use.

Field	Description
Time of Day	This represents the date and time from the real-time clock resident on the ControlWave Pump Controller. NOTE – this time may be different from the time on the PC.
Start Hour (0-23)	The hour when the restricted time of use starts. The restricted time of use will start exactly at the top of the hour.
End Hour (0-23)	The hour when the restricted time of use ends. The restricted time of use will end at the end of this hour.

Permissive Command	If the time-of-use control is enabled, then during the restricted time-of-use period, the permissive command will be set to OFF. This will prevent the pumps from operating, unless a start override command is issued. If the time-of-use control is disabled, or if the time-of-use control is enabled and the time of day is outside the restricted time-of-use period, the permissive command will be set to PERMIS. This will allow the pumps to be started by any primary control or override control.
Disable ?/ Enable ?	Use this button to disable or enable the restricted time-of-use control.

When finished, click on BACK.

3.13 Station Control

The ControlWave Pump Controller allows for alternating the LEAD, LAG 1 and LAG 2 pump starting order.

Configuration Wizard Select a Device Configure

LEAD/LAG CONTROLLER			
AUTO/MANUAL	MANUAL ?	AUTO	
MODE	ROTATION ?	RUNTIME	
PUMPS AVAILABLE	3		
	START COMMAND	STOP COMMAND	
LEAD PUMP	FALSE	FALSE	
LAG 1 PUMP	FALSE	FALSE	
LAG 2 PUMP	FALSE	FALSE	
PUMP CONTROLS			
PUMP NAME	PUMP 1	PUMP 2	PUMP 3
RANK	1	2	3
RUNTIME	0.0	0.0	0.0

BACK NEXT FINISH

 **Pump Station Controller** 

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
AUTO/MANUAL	When manual is selected, the operator may set the pump ranks manually. When auto is selected, the pump ranks are set automatically by the ControlWave Pump Controller, based on the mode (either RUNTIME or ROTATION) selected.
MODE	If the RUNTIME mode is selected, then the pump ranks are assigned by runtime, with rank 1 assigned to the pump with the least runtime and rank 3 assigned to the pump with the greatest runtime. If the ROTATION mode is selected, then ranks are changed after the pumps stop. The pump with rank 3 is assigned rank 2, the pump with rank 2 is assigned rank 1, and the pump with rank 1 is assigned rank 3.
PUMPS AVAILABLE	This represents the number of pumps available for control.
LEAD (LAG 1, LAG 2) START	The START command will be set to START if a start command is generated by any of the various control

(STOP) COMMAND	modes (discharge pressure primary control, discharge pressure override control, remote tank level primary control, etc.) If there are no start commands being generated, the START command will be set to FALSE. If there is both a START and STOP command present, the STOP command will override the START command.
LEAD (LAG 1, LAG 2) START (STOP) COMMAND	The STOP command will be set to STOP if a stop command is generated by any of the various control modes (discharge pressure primary control, discharge pressure override control, remote tank level primary control, etc.) If there are no stop commands being generated, the STOP command will be set to FALSE. If there is both a START and STOP command present, the STOP command will override the START command.
PUMP NAME	These are the descriptors assigned to the pumps during the pump configuration process.
RANK	This is the pump rank. If manual ranking is selected, these ranks can be changed by the user by right clicking on the field and selecting the rank to be assigned to the pump. If auto ranking is selected, the ranks are set by the ControlWave Pump Controller, and these fields cannot be written to.
RUNTIME	The runtime of the pump, in hours.

3.14 Chlorine Residual

If chlorine is monitored at this site, it may be monitored here using a chlorine monitor with a 4 – 20 mA output or an AquaSenors DataStick configured later in the Configuration Wizard.

Chlorine residual is not used for chemical dosing. Chemical dosing is paced by the station flow.

Click on CONFIGURE CL2 RESIDUAL MONITOR INPUT to configure the Chlorine Residual Monitor and see Section 3.14.1.

The screenshot shows the 'Configuration Wizard' interface. At the top, there is a 'Select a Device' dropdown menu and a 'Configure' button. Below this, a section titled 'Chlorine Residual Monitor' contains the question 'Is there a Chlorine Residual Monitor used at this site?'. There are two buttons: 'Yes' (highlighted in green) and 'No?'. Below the 'Yes' button is a button labeled 'CONFIGURE CL2 RESIDUAL MONITOR INPUT'. At the bottom of the wizard, there are three buttons: 'BACK', 'NEXT', and 'FINISH'. The footer of the interface includes the 'Bristol ControlWave' logo, the text 'Pump Station Controller', and the 'EMERSON' logo. A small copyright notice is visible at the bottom left: '© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.'

3.14.1 Configure CL2 Residual Monitor Input

Configuration Wizard - Input Configuration

CHLORINE RESIDUAL		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
RESIDUAL	0.0	100.0	UNITS	XMTR_DESC

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
RESIDUAL ZERO	Enter the ZERO value. This represents the chlorine residual value when the analog input is at 4 mA or 1 Volt).
RESIDUAL SPAN	Enter the SPAN value. The SPAN represents the difference between the chlorine residual value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt. For instance, if the ZERO is 0.0 FEET and the level at 20 mA is 35.0 FEET, the SPAN is 35.0. If the ZERO is 35.0 FEET and the level at 20 mA is 45.0 FEET, the SPAN is 10.0.
RESIDUAL UNITS	Enter the engineering units indicating chlorine residual.
RESIDUAL DESCRIPTOR	Enter a descriptor for the chlorine residual monitor. This descriptor will be used throughout the rest of the menus to represent the chlorine residual monitor.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.15 Configure pH Monitor

If pH is monitored at this site, it may be monitored here using a pH monitor with a 4 – 20 mA output or an AquaSenors DataStick configured later in the Configuration Wizard.

The pH reading is not used for control.

To configure the Ph Monitor, click on CONFIGURE pH MONITOR INPUT, and see Section 3.15.1.

3.15.1 Configure pH Monitor Input

pH MONITOR	ZERO	SPAN	UNITS	ALARM LIMITS
RESIDUAL	0.0	100.0	UNITS	XMTR_DESC

BACK

Bristol ControlWave Pump Station Controller EMERSON

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
pH ZERO	Enter the ZERO value. This represents the pH value when the analog input is at 4 mA or 1 Volt).
pH SPAN	Enter the SPAN value. The SPAN represents the difference between the pH value when the analog input is 20 mA or 5 Volts and when the analog input is at 4 mA or 1 Volt
pH UNITS	Enter the engineering units indicating level. Typically, this would be pH.
pH DESCRIPTOR	Enter a descriptor for the pH Monitor.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

When finished, click on BACK.

3.16 Chemical Feed Pump

A chemical Feed pump can be controlled to produce a fixed feed rate such as ml/minute.

Configuration Wizard - Input Configuration

CHEMICAL FEED PUMP		ALARM LIMITS		
	ZERO	SPAN	UNITS	DESCRIPTOR
SPEED OUTPUT	0.0	100.0	ml/min	METERING PUMP

Field	Description
ZERO	Enter the ZERO value. This represents the value when the analog output is at 4 mA or 1 Volt).
SPAN	Enter the SPAN value. The SPAN represents the difference between the value when the analog output is 20 mA or 5 Volts and when the analog output is at 4 mA or 1 Volt
UNITS	Enter the engineering units indicating the fixed speed rate.
DESCRIPTOR	Enter a descriptor for the Chemical Feed Pump.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

3.17 Rain Gauge

A Rain Gauge input may be used.

Configuration Wizard Select a Device Configure

RAIN GAUGE

Is there a Rain Gauge used at this site?

Yes **No?**

CONFIGURE RAIN GAUGE INPUT

BACK **NEXT** **FINISH**

Bristol ControlWave **Pump Station Controller** **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Click on CONFIGURE RAIN GAUGE INPUT and see Section 3.17.1.

3.17.1 Configure Rain Gauge Input

Configuration Wizard - Input Configuration

RAIN GAUGE			
	K FACTOR (VOLUME PER PULSE)	UNITS	DESCRIPTOR
RAIN GAUGE	1.000	GALS	TOTALS

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
K FACTOR (VOLUME PER PULSE)	A multiplier supplied by the rain gauge manufacturer. See Section 3.5.3 for a discussion of K Factor.
UNITS	Enter the engineering units here.
DESCRIPTOR	Enter a descriptor for the rain gauge.

When finished, click on BACK.

3.18 I/O Configuration

The final configuration step is to configure the I/O.

The screenshot shows the 'Configuration Wizard' window. At the top, there is a 'Select a Device' dropdown menu and a 'Configure' button. Below this is a section titled 'IO CONFIGURATION'. It contains a table with two columns: a text column and a button column. The first row has a text box with the link 'Use this link to go to the I/O Configuration Page' and a 'CONFIGURE ALL IO' button. The second row has a text box asking 'Is the chlorine residual monitored by an AquaSensor Data Stick?' with 'No' and 'Yes?' buttons, and a 'CONFIGURE CL2 PROBE' button. The third row has a text box asking 'Is the pH monitored by an AquaSensor Data Stick?' with 'No' and 'Yes?' buttons, and a 'CONFIGURE pH PROBE' button. At the bottom of the wizard are three buttons: 'BACK', 'NEXT', and 'FINISH'. The footer includes the Bristol ControlWave logo, the text 'Pump Station Controller', and the Emerson logo. A small copyright notice is also present: '© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.'

IO CONFIGURATION	
Use this link to go to the I/O Configuration Page	CONFIGURE ALL IO
Is the chlorine residual monitored by an AquaSensor Data Stick?	No Yes? CONFIGURE CL2 PROBE
Is the pH monitored by an AquaSensor Data Stick?	No Yes? CONFIGURE pH PROBE

BACK NEXT FINISH

Bristol ControlWave **Pump Station Controller** **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.


To go to the I/O Configuration page, click on CONFIGURE ALL IO and see Section 3.18.1.

If you have an AquaSensor Data Stick to monitor Chlorine residual, click on CONFIGURE CL2 PROBE and see Section 3.18.2.

If you have an AquaSensor Data Stick to monitor pH, click on CONFIGURE pH PROBE and see Section 3.18.3.

3.18.1 Configure All I/O

A warning appears as a reminder to ensure that the system is in a safe mode prior to making I/O configuration changes. Click on **[OK]** to proceed.



MAX IO					
DI	DO	AI	AO	HSC	
10	4	3	1	4	

PUMPS								
DEVICE	RUN STATUS DI POINT	REMOTE DI POINT	LOCAL DI POINT	TROUBLE DI POINT	POWER FAIL DI POINT	TAGOUT DI POINT	START DO POINT	STOP DO POINT
PUMP 1	DI 1	Always Off	Always Off	Always Off	Always Off	Always Off	DO 1	Always Off
PUMP 2	DI 2	Always Off	Always Off	Always Off	Always Off	Always Off	DO 2	Always Off
PUMP 3	DI 3	Always Off	Always Off	Always Off	Always Off	Always Off	DO 3	Always Off
VFD 1	DI 4	Always Off	Always Off	Always Off	Always Off	Always Off	Always Off	Always Off

TANK FLOATS				
DEVICE	HIHI FLOAT DI POINT	HI FLOAT DI POINT	LO FLOAT DI POINT	LOLO FLOAT DI POINT
TANK 1	Always Off	DI 5	Always Off	Always Off

BUILDING SECURITY		
DEVICE	INTRUSION DI	INTRUSION DISABLE DI
INTRUSION	DI 6	Always Off

ANALOG INPUTS		ALARM LIMITS				
DEVICE	VALUE	AI POINT	ZERO	SPAN	UNITS	DESCRIPTOR
FLOW	0.000	Zero	0.000	100.000	GPM	FLOW
SUCTION PRESSURE	0.000	Zero	0.000	100.000	PSI	SUCTION

MAX I/O

This area provides information regarding the amount of I/O available considering the ControlWave model you are using.

Field	Description
DI, DO, AI, AO, HSC	Based on the specified type of ControlWave model you are using, this indicates the maximum number of I/O points of each type: DI (Discrete Input), DO (Discrete Output), AI (Analog Input), AO (Analog Output), or HSC (High Speed Counter). NOTE: For mixed I/O boards, the Pump Controller Application has no way to detect which I/O is actually available, since, some I/O is configured only by jumpers on the hardware. As a result, these fields only display the maximum I/O that <i>might</i> be present, based on the board type.

PUMPS

There are up to six inputs and two outputs that may be connected for each pump. The physical I/O available in the ControlWave model, and the indicator signals available from the particular model of pump, determine the number points you may assign to these inputs or outputs. Always On and Always Off are selectable when there is no connection to a physical input or output.

Field	Description
DEVICE	Identifies the pump to which the I/O is connected.
RUN STATUS DI POINT	This DI point indicates whether or not the pump is actually running. Select the appropriate DI that reports this status. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.
REMOTE DI POINT	If the pump is wired to a two-wire REMOTE-LOCAL switch, or a three-wire HAND-OFF-AUTO switch, specify the DI associated with the REMOTE or AUTO function. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.
LOCAL DI POINT	If the pump is wired to a two-wire REMOTE-LOCAL switch, specify the DI associated with the LOCAL function. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.
TROUBLE DI POINT	If the pump has a trouble-indicator that can be wired to a DI, specify the DI associated with that function here. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.

POWER FAIL DI POINT	If the pump has a power fail-indicator that can be wired to a DI, specify the DI associated with that function here. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.
TAGOUT DI POINT	If the pump has a 'Tagout' indicator, that means that the pump is out-of-service for maintenance or repair, specify the DI associated with that function here. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application. NOTE: All start commands for this pump via the Pump Controller Application are stopped if this DI is ON.
START DO POINT	Specify the DO used to start the pump here. If you don't have a DO that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.
STOP DO POINT	Specify the DO used to stop the pump here. If you don't have a DO that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.

TANK FLOATS

Discrete inputs not assigned to the pumps are available for tank float inputs or building security.

Field	Description
DEVICE	Identifies the tank to which the I/O is connected.
HI HI FLOAT DI POINT	This DI point is used to indicate that the tank float level has exceeded the HI HI alarm level. Specify the DI associated with this level, or, if you don't have a DI for this function available, specify either 'Always Off' or 'Always On' as appropriate to your application.
HI FLOAT DI POINT	This DI point is used to indicate that the tank float level has exceeded the HI alarm level. Specify the DI associated with this level, or, if you don't have a DI for this function available, specify either 'Always Off' or 'Always On' as appropriate to your application.
LO FLOAT DI POINT	This DI point is used to indicate that the tank float level has reach the LO alarm level. Specify the DI associated with this level, or, if you don't have a DI for this function available, specify either 'Always Off' or 'Always On' as appropriate to your application.
LO LO FLOAT DI POINT	This DI point is used to indicate that the tank float level has reach the HI HI alarm level. Specify the DI associated with this level, or, if you don't have a DI for this function available, specify either 'Always Off' or 'Always On' as appropriate to your application.

BUILDING SECURITY

Discrete inputs not assigned to the pumps are available for tank float inputs and building security.

Field	Description
DEVICE	Identifies the building security device.
INTRUSION DI	This DI point indicates intrusion detection. Select the appropriate DI that reports this status. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.
INTRUSION DISABLE DI	This DI point disables the intrusion detection DI. If you don't have a DI that performs this function, choose either 'Always Off', or 'Always On', as appropriate to your application.

ANALOG INPUTS / ANALOG OUTPUTS

Analog inputs or outputs may be assigned to the AI POINT or AO POINT fields, respectively

Field	Description
DEVICE	Identifies the device associated with the input or output.
VALUE	The current value of the AI or AO. If the input or output has no physical connection, the VALUE will be the ZERO value.
AI POINT / AO POINT	Select the appropriate AI or AO for the DEVICE. A Zero in the cell indicates that there is no connection to a physical input or output; in this case the value in the VALUE field will be the same value entered in the ZERO field.
ZERO	Enter the ZERO value. This represents the value when the analog input (or output) is at 4 mA or 1 Volt).
SPAN	Enter the SPAN value. The SPAN represents the difference between the value when the analog input (or output) is 20 mA or 5 Volts and when it is at 4 mA or 1 Volt.
UNITS	Enter the engineering units here.
DESCRIPTOR	Enter a descriptor here. This descriptor will be used throughout the rest of the menus.

ANALOG INPUTS		ALARM LIMITS				
DEVICE	VALUE	AI POINT	ZERO	SPAN	UNITS	DESCRIPTOR
FLOW	-24.986	AI 1	0.000	225.000	GPM	FLOW
SUCTION PRESSURE	0.000	Zero	0.000	100.000	PSI	SUCTION
DISCHARGE PRESSURE	0.000	Zero	0.000	100.000	PSI	DISCHARGE
CL2 RESIDUAL	0.000	Zero	0.000	100.000	ppm	CL2 RESIDUAL
pH MONITOR	7.000	Zero	7.000	7.000	UNITS	pH
REMOTE LEVEL	0.000		0.000	100.000	FEET	RESERVOIR
LEVEL	-24.980	AI 2	10.000	30.000	FEET	CLEARWELL
VOLUME	-116.600		0.000	100.000	MGAL	CLEARWELLVOLUME
WELL DRAWDOWN LEVEL	0.000	Zero	0.000	100.000	FEET	DRAWDOWN
VFD SPEED FEEDBACK	-24.994	AI 3	0.0	100.0	%	VFD 1

ANALOG OUTPUTS		ALARM LIMITS				
DEVICE	VALUE	AO POINT	ZERO	SPAN	UNITS	DESCRIPTOR
METERING PUMP	0.000	Zero	0.000	100.000	%	METERING PUMP
VFD	0.0	AO 1	0.000	100.000	Hz	VFD 1

HIGH SPEED COUNTERS

Analog inputs or outputs may be assigned to the AI POINT or AO POINT fields, respectively

Field	Description
DEVICE	Identifies the device associated with the high speed counter.
HSC POINT	Specify the HSC point associated with the DEVICE.
K FACTOR (VOLUME PER PULSE)	A multiplier supplied by the Meter manufacturer. See Section 3.5.3 for a discussion of K Factor.
UNITS	Enter the engineering units here.
FLOW TOTALIZATION METHOD	The flow totalization method is shown here. Flow totalization may be enabled / disabled from the associated button.

To configure alarm limits, click on ALARM LIMITS. (See Section 3.6 for details.)

Once you have finished configuring all I/O points, select 'BACK' at the bottom of the page.

3.18.2 Configure CL2 Probe

If using an AquaSensor Chlorine DataStick, it should be connected to communication port 3 which is an RS 485 port. Data Sticks may be multi-dropped with a unique address for each. The Pump Control application is pre-configured for a Chlorine Data Stick with address 1.

Configuration Wizard - Input Configuration

Cl2 AquaSensor Data Stick			
	PORT	ADDRESS	
COMM SETUP	3	1	
	DESCRIPTION	TYPE	
SENSOR INFO	AIT101	0	
	VALUE	TEMPERATURE	STATUS
LIVE DATA	0.000	0.0	-8002

BACK


Pump Station Controller


© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
PORT	Identifies the port on the ControlWave Pump Controller.
ADDRESS	The AquaSensor address.
DESCRIPTION	A description of the AquaSensor data stick.
TYPE	The type is displayed here.
VALUE	The current live reading from the AquaSensor data stick.
TEMPERATURE	The current temperature reading.
STATUS	Communications status. Negative values indicate bad communications; a 0 indicates good communications.

When finished, click on BACK.

3.18.3 Configure pH Probe

If using an AquaSensor pH DataStick, it should be connected to communication port 3 which is an RS 485 port. Data Sticks may be multi-dropped with a unique address for each. The Pump Control application is pre-configured for a pH Data Stick with address 2.

Configuration Wizard - Input Configuration

pH AquaSensor Data Stick			
	PORT	ADDRESS	
COMM SETUP	3	2	
	DESCRIPTION	TYPE	
SENSOR INFO	AIT102	0	
	VALUE	TEMPERATURE	STATUS
LIVE DATA	0.000	0.0	-8002

BACK

Bristol ControlWave Pump Station Controller **EMERSON**

© 2007 Remote Automation Solutions, division of Emerson Process Management. All rights reserved. The Emerson logo is a trademark and service mark of Emerson Electric Co.

Field	Description
PORT	Identifies the port on the ControlWave Pump Controller.
ADDRESS	The AquaSensor address.
DESCRIPTION	A description of the AquaSensor data stick.
TYPE	The type is displayed here.
VALUE	The current live reading from the AquaSensor data stick.
TEMPERATURE	The current temperature reading.
STATUS	Communications status. Negative values indicate bad communications; a 0 indicates good communications.

When finished, click on BACK.

3.19 Recipe

When the configuration and setup is completed, click on 'NEXT' at the bottom of the page to advance to the Recipe page.

The Recipe page allows the user to save a set of initial values for the variables in the ControlWave Pump Controller application, in a file at the PC. The values to be saved in the recipe file can be loaded directly from the ControlWave Pump Controller application, or the user can type them in manually.

At any later time, the user can load the values from the file into the associated variables in the application. This can be useful, for example, if various tuning parameters for the optimum performance of the application have been determined, and they should be saved for later use. This also allows a pump control configuration to be easily modified for use at other similar pump sites without having to do re-do the entire configuration at the other sites.

A default recipe file is included that you can use to upload or download configuration values for the application. You may also edit this file, or create your own recipes as described in Section 3.19.1.

Configuration Wizard [Select a Device] [Configure]

Station Name

TEST_STATION	Configuring
--------------	-------------

[Load from RTU] [Load from File] [Modify Signal]
 [Write to RTU] [Write to File] [Delete Signal]
 [Floating Point Format] [Load Signal List] [Insert Signal]

Total Signals : 596


Recipe Parameters

Filename : C:\OpenBSI\WebWaterApp\Config\DefaultMH20.rcp [Browse]

	Signal Name	Value	Status
1	ST1.STATION_ID	TEST_STATION	
2	ST1.MAX_DEVICES	3.0000	
3	ST1.PROBE_1_INCLUDE	OFF	
4	ST1.PROBE_2_INCLUDE	OFF	
5	ST1.VFD1_INCLUDE	ON	
6	ST1.P1_INCLUDE	ON	
7	ST1.P2_INCLUDE	ON	
8	ST1.P3_INCLUDE	ON	
9	ST1.FLOAT_CTRL_INCLUDE	ON	
10	ST1.INTRUSION_INCLUDE	ON	

3.19.1 Creating a Recipe


To create a recipe you must first specify the variables you want included in the recipe. One way to do this is to *either* right-click on the grid in the center of the Recipe page and choose "**Insert Signal**" from the pop-up menu, *or* click on the **[Insert Signal]** button.



In either case, a dialog box will appear in which you can enter the variable's name. If desired, you can also enter a value for the variable. Click on **[OK]** when you are finished. Repeat for each additional variable. Up to 1000 variables can be included in a recipe.


If you don't enter values for the variable when you insert the variable, you can load the current values in the running control strategy for all variables in the recipe by clicking on **[Load from RTU]**.

Another way to specify variables for the recipe is to load the variables from a signal list. To do this, click on the **[Load Signal List]** button, then specify the number of the signal list and click on **[OK]**.




If, as you are creating the recipe, you decide you want to change a variable or value for a particular entry, *either* right click on the entry and choose "**Edit Signal**" from the pop-up menu, *or* click on the **[Modify Signal]** button. Make changes, as desired, and click on **[OK]**.

If you want to delete a variable in the recipe, *either* right-click on the line for that variable and choose "**Delete Signal**" from the pop-up menu, *or* click on the **[Delete Signal]** button. You will be prompted to confirm the deletion.



3.19.2 Changing the Floating Point Format of Values

If desired, you can change the format in which values are displayed in the recipe window by clicking on the **[Floating Point Format]** button.



Use the "**Width**" list box to specify the total number of characters in the field (including the decimal point) when displaying a floating point number. This can range from 0 to 15. The default is 12.


Use the "**Precision**" list box to choose the number of places to the right of the decimal point which should be displayed. This can range from 0 to 15. The default is 6.

Use the "**Exponent**" list box to choose the floating point format 'f', exponential notation 'e', or choose 'g' to have the Recipe control choose the best fit format.

Click on **[OK]** when finished.

3.19.3 Saving the Recipe

Type the path and filename for your recipe file in the "**Filename**" field or use the **[Browse]** button to specify the path, then type the name. Standard recipe files are stored with a file extension of (.RCP). You also have the option of saving the file as a .CFG file (which is intended for use with Coastal Flow Measurement Inc. Flow-Cal™ software.)



Once you have specified the path and filename, click on the **[Write to File]** button, and the recipe will be written to the specified file.

3.19.4 Recalling a Saved Recipe, and Sending Its Values to the Pump Controller

To recall a recipe which you have saved previously, use the **[Browse]** button to locate it, or type its path and filename in directly in the "**Filename**" field. Finally, click on the **[Load from File]** button, and the recipe will be brought into the web page.

Once the recipe file has been loaded, you can send the recipe values to the controller by clicking on the **[Write to RTU]** button.

3.20 Saving the Configuration

When the configuration and setup is completed, click on 'Finish?'. The configuration may be Saved, Canceled or returned to Factory Defaults by right clicking in the SAVE field. Selecting CLOSE will automatically advance to the I/O Checkout page.


When finished, would you like to SAVE your changes, CANCEL your changes, or RESTORE FACTORY DEFAULTS?		
	SAVE	
Complete configuration for this RTU?	Configuring	Finish?

Chapter 4 – Start Up

This chapter discusses the Start Up pages. These pages include the basic steps for starting the Pump Controller application, and verifying that it is operating correctly.

In This Chapter

4.1	I/O Checkout.....	4-2
4.2	SLC Tuning.....	4-3
4.3	Pump Checkout	4-4
4.3.1	Permissive and Interlock Details	4-7



For information on I/O Checkout, see Section 4.1.

For information on SLC Tuning, see Section 4.2.

For information on Pump Checkout, see Section 4.3

For details on System Information, see Section 2.3.

4.1 I/O Checkout

The I/O Checkout page is the same as the I/O Configuration page but shows live data rather than point configuration. This allows monitoring and checkout of all I/O.

See section 3.18 for details on the meaning of the various fields.

I/O Checkout

MAX IO

	DI	DO	AI	AO	HSC	
	10	4	3	1	4	

PUMPS

DEVICE	RUN STATUS STATE	REMOTE STATE	LOCAL STATE	TROUBLE STATE	POWER FAIL STATE	TAGOUT STATE	START DO STATE	STOP DO STATE
PUMP 1	STOP_D	OFF	OFF	OK	OK	OK	OFF	OFF
PUMP 2	STOP_D	OFF	OFF	OK	OK	OK	OFF	OFF
PUMP 3	STOP_D	OFF	OFF	OK	OK	OK	OFF	OFF
VFD 1	STOP_D	OFF	OFF	OK	OK	OK	OFF	OFF

TANK FLOATS

DEVICE	HIHI FLOAT STATE	HI FLOAT STATE	LO FLOAT STATE	LOLO FLOAT STATE	
TANK 1	OFF	OFF	OFF	OFF	

BUILDING SECURITY

DEVICE	INTRUSION STATEDI	DISARM STATE	
INTRUSION	OFF	OFF	

ANALOG INPUTS

ALARM LIMITS


DEVICE	VALUE		ZERO	SPAN	UNITS	DESCRIPTOR
FLOW	0.00		0.00	225.00	GPM	FLOW
SUCTION PRESSURE	0.00		0.00	100.00	PSI	SUCTION
DISCHARGE PRESSURE	0.00		0.00	100.00	PSI	DISCHARGE

4.2 SLC Tuning

The SLC tuning page allows on-line tuning of the control loop. The setpoint is configurable as well as the KP, KI & KD tuning parameters. PV1 or PV2 may be manually selected or set to automatic for override control. The output can also be placed in manual mode to manually set the output valve.

Note: For a description of the tuning parameters and procedures, see the PID3TERM page of the ACCOL3 online help, in ControlWave Designer.

A live real-time trend is used to assist in optimizing the loop tuning.



Field	Description
PV DESCRIPTION	A textual description of the control loop.
PV VALUE	The process variable's value.
SP VALUE	The setpoint, or desired value for the process variable.
SELECTOR	Only one loop may be tuned at a time. Select either 'Loop 1' or 'Loop 2' for tuning. If a loop is selected for tuning, its associated button will say 'Loop x Selected'.
MANUAL CONTROL	This button toggles control between 'Auto' and 'Manual'. When auto, the loop calculations determine the value of the MV; when manual, MV is set to the MANUAL OUTPUT value.
MANUAL OUTPUT	Specify a value for the output when manual control is active.
MV	The value of manipulated variable (output).
KP	The proportion constant (gain).
KI	The integral time (in repeats per minute).
KD	The derivative rate constant (in minutes).
DEADBAND	Is a positive number used to reduce fluctuations of the output based on minor changes in the input.

4.3 Pump Checkout

The pump startup page allows selection of Auto/Manual mode for each of the pumps. In Manual mode the pumps can be started and stopped provided the Permissive and Interlock conditions are met. If a pump is not starting or stopping as expected, the Permissive and Interlock Details may be selected.

Pump Startup

PUMP NAME	VFD 1		PUMP 1		PUMP 2		PUMP 3	
COMPUTER A/M	MANUAL ?	AUTO	MANUAL ?	AUTO	AUTO ?	MANUAL	MANUAL ?	AUTO
START	N/A	OFF	N/A	OFF	START ?	OFF	N/A	OFF
STOP	N/A	OFF	N/A	OFF	STOP ?	OFF	N/A	OFF
SPEED	0.0 %	0.0 HZ						
AVAILABLE	OFF		OFF		OFF		OFF	
REMOTE	OFF		OFF		OFF		OFF	
LOCAL	OFF		OFF		OFF		OFF	
PERMISSIVE	PERMIS		PERMIS		PERMIS		PERMIS	
INTERLOCK	INTLCK		INTLCK		INTLCK		INTLCK	
PERMISSIVE AND INTERLOCK DETAILS								
RUN STATUS	STOP_D		STOP_D		STOP_D		STOP_D	
RUNTIME	0.0		0.0		0.0		0.0	
FAIL	OK	RESET ?	OK	RESET ?	OK	RESET ?	OK	RESET ?

Field	Description
PUMP NAME	The name of the pump.
COMPUTER A/M	For each pump, a button is provided to toggle its mode between AUTO and MANUAL. The current mode is also displayed.
START	A START button is provided for each pump. If the button label is 'N/A', the pump is not in MANUAL mode or not configured yet. The current running state of the pump is also displayed.
STOP	A STOP button is provided for each pump. If the button label is 'N/A', the pump is not in MANUAL mode or not configured yet. The current running state of the pump is also displayed.
SPEED	The field on the left shows the manual speed input; the field on the right is the actual speed.
AVAILABLE	Displays whether or not the pump is available. If a pump is not available, it cannot be started/stopped.
REMOTE	Displays whether the pump is in REMOTE mode.
LOCAL	Displays whether the pump is in LOCAL mode.
PERMISSIVE	If PERMIS is displayed, a permissive override is supported for this pump.
INTERLOCK	If INTLCK is displayed, no override is allowed from any pump control.

RUN STATUS	Displays the current running status of the pump.
RUNTIME	The accumulated running time of the pump is displayed here.
FAIL	Indicates a pump failure. To clear the failure status indication, click on the RESET button.

Manually Starting/Stopping a Pump

To start or stop a pump, manually, follow these steps:

- 1.** Check to see that the pump is currently in MANUAL mode. If not, click on the MANUAL? button, to put it into MANUAL mode.
- 2.** Click on START? to start the pump, or STOP? to stop the pump.
- 3.** Check the RUN STATUS field to whether the pump changes status, as desired.
- 4.** If the pump does not start/stop as desired, check the permissive and interlock details, and review other possible error conditions.

To view information about overrides for each pump, click on PERMISSIVE AND INTERLOCK DETAILS and see Section 4.3.1.

4.3.1 Permissive and Interlock Details

This page shows permissive and interlock status for all configured pumps.

Pump Interlocks and Permissives								
PUMP DETAILS								
PUMP NAME	VFD 1		PUMP 1		PUMP 2		PUMP 3	
AVAILABLE	OFF		OFF		OFF		OFF	
REMOTE	OFF		OFF		OFF		OFF	
LOCAL	OFF		OFF		OFF		OFF	
STARTS HR	OK		OK		OK		OK	
STARTS DAY	OK		OK		OK		OK	
TAGOUT	OK		OK		OK		OK	
PERMISSIVE	PERMIS		PERMIS		PERMIS		PERMIS	
INTERLOCK	INTLCK		INTLCK		INTLCK		INTLCK	
RUN STATUS	STOP_D		STOP_D		STOP_D		STOP_D	
RUNTIME	0.0		0.0		0.0		0.0	
FAIL	OK	RESET ?	OK	RESET ?	OK	RESET ?	OK	RESET ?
INTERLOCKS AND PERMISSIVE (COMMON TO ALL PUMPS)								
	Live Value		Override Type		Stop Setpoint		Command	
SUCTION	0.0	PSI	PERMIS		0.0		OFF	
DISCHARGE	0.0	PSI	PERMIS		0.0		OFF	
CLEARWELL	10.0	FEET	PERMIS		0.0		OFF	
RESERVOIR	0.0	FEET	PERMIS		0.0		OFF	
DRAWDOWN	0.0	FEET	PERMIS		0.0		OFF	
TIME OF USE			PERMISSIVE				PERMIS	

Field	Description
PUMP NAME	The name of the pump.
AVAILABLE	Displays whether or not the pump is available. If a pump is not available, it cannot be started/stopped.
REMOTE	Displays whether the pump is in REMOTE mode.
LOCAL	Displays whether the pump is in LOCAL mode.
STARTS HR	Displays whether the pump has exceeded its scheduled number of starts per hour.
STARTS DAY	Displays whether the pump has exceeded its scheduled number of starts per day.

TAGOUT	If the pump is in Tagout (out-of-service for maintenance or repair) the pump cannot be started by any control method.
PERMISSIVE	If PERMIS is displayed, a permissive override is supported for this pump.
INTERLOCK	If INTLCK is displayed, no override is allowed from any pump control.
RUN STATUS	Displays the current running status of the pump.
RUNTIME	The accumulated running time of the pump is displayed here.
FAIL	Indicates a pump failure. To clear the failure status indication, click on the RESET button.
Live Value	The value of the process variable, upon which, it is decided to start or stop the pump.
Override Type	Displays the override type currently active; either permissive or interlock.
Stop Setpoint	If this live value falls below this value, a STOP command is issued to the pump.
Command	Displays any COMMAND currently issued to the pump.
TIME OF USE	Displays the last time the pump ran.

When all pump checkout is completed, the window may be closed to return to the main Pump Controller TechView window.


Chapter 5 – Operation

This chapter covers the 'Operate' tab. The Operate tab allows direct access to the I/O Setting, Pump Operation, Fixed Speed Pump Settings, SLC Control Setting and System Information pages.

In This Chapter

5.1 Fixed Speed (FS) Pump Control Settings5-2

Typically, this page would be used by Operators or Technicians, after configuration has been completed.



For information on I/O Settings, see Section 4.1.

For information on Pump Operation, see Section 4.3.

For details on System Information, see Section 2.3.

For information on SLC Control Settings, see Section 4.2.

Fixed Speed Pump Control Settings are discussed in the next section.

5.1 Fixed Speed (FS) Pump Control Settings

This page brings together details on the fixed speed, non-VFD pumps in a single place.

Fixed Speed Pump Control Settings				
FIXED SPEED PUMP CONTROL SETTINGS				
Description	Live Value	Primary Controls	Override Controls	History
		Modify		
			Modify	View
		Modify	Modify	View
		Modify	Modify	View
		Modify	Modify	View
			Modify	View
Timeclock		Modify	Modify	

MISCELLANEOUS				
Description	Live Value	Control		History
				View
				View
				View
		Modify		View
				View

Field	Description
Description	A user-defined description of the pump or device.
Live Value	The current reading of the process variable which dictates whether or not the device should be started or stopped.
Primary Controls – Modify	Click on this button to change the start and stop setpoints for the device. See Section 3.3.2.
Override Controls – Modify	Click on this button to change the override settings for the device.
History - View	Click on this button to see running average, minimum, and maximum calculations for the process variable over the current hour, previous hour, current day, and previous day.
Timelock Modify	Click on these buttons to modify the timelock configuration, and override settings.


Chapter 6 – Logs

This chapter covers the 'Logs' tab. The Logs tab allows direct access to historical data in the ControlWave Pump Controller.

In This Chapter

6.1	View Archives	6-2
6.2	View Audit Trail	6-6
6.3	Collection	6-9

The ControlWave Pump Controller logs and stores time-stamped historical data in the RTU. This data may be accessed, viewed, collected and stored on the PC.



To view archive files, click on **[View Archives]** and see Section 6.1.

To view audit trail data, click on **[View Archives]** and see Section 6.2.

To view the Historical Log Collection, click on **[Collection]** and see Section 6.3.

6.1 View Archives

Hourly, Daily and Periodic historical Archives are logged in the ControlWave Pump Controller.

The data values will be displayed in the format selected with the 'Floating Point Format' button.

View Logs

Daily Archive Number	Hourly Archive Number	Periodic Archive Number
1	2	3

Collect Data

Save Parameters

Search Criteria

Floating Point Format

File Definition

Archive Collection Parameters

☐ Collect by Name
 ☐ Start from oldest record
 ☒ Freeze Date/Time

File Number :
 File Name :

Stats
 Fields Collected:
 Records Collected:

Record	DATE/TIME	LSN	GSN	SUCT_MIN	SUCT_MAX
1	13:03:32.000 28-MAR-2008	2083	140	-24.98	0.00
2	12:00:00.000 28-MAR-2008	2082	360	0.00	0.00
3	11:00:00.000 28-MAR-2008	2081	290	0.00	0.00
4	10:00:00.000 28-MAR-2008	2080	228	-24.98	0.00
5	09:13:16.000 28-MAR-2008	2079	166	-24.98	0.00
6	08:00:00.000 28-MAR-2008	2078	11455	0.00	0.00
7	07:00:00.000 28-MAR-2008	2077	11394	0.00	0.00
8	06:00:00.000 28-MAR-2008	2076	11333	0.00	0.00
9	05:00:00.000 28-MAR-2008	2075	11272	0.00	0.00
10	04:00:00.000 28-MAR-2008	2074	11211	0.00	0.00
11	03:00:00.000 28-MAR-2008	2073	11150	0.00	0.00
12	02:00:00.000 28-MAR-2008	2072	11089	0.00	0.00
13	01:00:00.000 28-MAR-2008	2071	11028	0.00	0.00
14	00:00:00.000 28-MAR-2008	2070	10967	0.00	0.00


The Hourly and Daily logs contain Min. Max, Avg. & Total values for the following measurements:

- Suction Pressure
- Discharge Pressure
- Flow
- Level
- Volume
- Chemical Feed
- Chlorine Residual

Pump Runtimes and Starts are also logged in the Hourly and Daily logs.

The Periodic log stores the following parameters per minute for seven days.


- Suction Pressure
- Discharge Pressure
- Flow
- Pump Run Status
- Chemical Feed
- Chlorine Residual

Field	Description
Collect by Name	Disabled for this application.
Start from oldest record	If you would like the oldest archive file entries to appear first, select this option.
Freeze Date/Time	As you scroll through the archive file window, the first column (which may contain date/time stamps) may disappear from the window as higher numbered columns are brought into the window. To prevent this, select this option.
File Number	This is the unique ID number for the Archive File you want to view. The file number is the log number. Valid entries are 1 for Daily, 2 for Hourly and 3 for Periodic.
File Name	This displays the archive file name of the Archive File you want to view, based on the number you selected.
Fields Collected	Displays the number of fields (columns) in the archive file which have been collected.
Records Collected	Displays the number of records (rows) in the archive file which have been collected.
Collect Data	Click on this button to collect archive data based on your entries in the "Archive Collection Parameters" section.
Save Parameters	This button calls up the Save Parameters dialog box. You can save the archive data you have viewed into a file on your PC hard disk.  To save the archive data, check the "Save Archive Data" check box, then enter a filename in the "Filename" field, or choose the [...] button to locate a path and filename of a file. NOTE: This only saves a snapshot of the data you have actually viewed on the screen; it does NOT save the entire archive file. As you scroll to bring new data on the screen, it will be added to the specified file. If you want to save an entire Archive File, you should use a tool such as the Open BSI Harvester or the Historical Log Storage control.

Click on **[OK]** when finished.

Search Criteria

This button calls up the Select Data Collection Criteria dialog box.



This dialog box allows you to filter the archive data which will be displayed.

"Collect All Available Information" specifies that all archive data from this archive file should be collected.


"Collect by specified Date" specifies that only archive data with timestamps between the **"Begin Date"** and **"End Date"** entries you specify should be collected.

"Collect by specified Period" specifies that only archive data collected during the period you specify should be collected. Choices are 'Today', 'This Week', or 'This Month'.

Click on **[OK]** when you have finished selecting the search criteria, or **[Cancel]** to exit without saving changes.

Floating Point Format

Calls up the Float Format dialog box. In this dialog box, you can specify the precision with which analog (floating point) values are displayed.



Use the **"Width"** list box to specify the total number of characters in the field (including the decimal point) when displaying a floating point number. This can range from 1 to 15. The default is 12.

Use the **"Precision"** list box to choose the number of places to the right of the decimal point which should be displayed. This can range from 0 to 15. The default is 6.

Use the **"Exponent"** list box to choose the floating point format 'f', exponential notation 'e', or choose 'g' to have the Archive Collection control choose the best fit format.

Click on **[OK]** when finished.

File Definition	This button displays certain configuration parameters for this archive file, e.g. number of records. NOTE: These parameters CANNOT be changed here, they are only displayed.
------------------------	--

6.2 View Audit Trail

Audit trail data may be collected from the ControlWave Pump Controller. Audit trail data includes alarms and a log of significant system events.

Station Audit Trail

Collect Data

Data Storage


Search Criteria

Total # of Records Collected: 60

	Date/Time	Signal	Description	Audit Seq#	Global Seq#
1	13:55:22.390 12-JUN-2008	COLD START		3587	12
2	13:55:23.450 12-JUN-2008	ST1.FLOW.VALUE	-24.98999 LOLO C-ALM (-1C	3588	14
3	13:55:23.480 12-JUN-2008	ST1.SUCTION.VALU	-24.98599 LOLO C-ALM (-1C	3589	16
4	13:55:23.520 12-JUN-2008	ST1.DISCHARGE.VA	-24.97998 LOLO C-ALM (-1C	3590	18
5	13:55:25.790 12-JUN-2008	ST1.INTRUSION.AL	INTRDR C-ALARM	3591	20
6	13:58:24.670 12-JUN-2008	PLC STOP		3592	21
7	13:58:33.220 12-JUN-2008	WARM START		3593	22
8	13:58:34.770 12-JUN-2008	ST1.INTRUSION.AL	INTRDR C-RETURN TO NORMAL	3594	24
9	13:58:36.070 12-JUN-2008	ST1.INTRUSION.AL	INTRDR C-ALARM	3595	26
10	10:17:17.910 13-JUN-2008	ST1.TCSETUP.TC00	FALSE TO TRUE STATUS CHA	3596	49
11	10:17:33.510 13-JUN-2008	ST1.TCSETUP.TC02	FALSE TO TRUE STATUS CHA	3597	50
12	10:17:49.910 13-JUN-2008	ST1.TCSETUP.TC01	FALSE TO TRUE STATUS CHA	3598	51
13	10:18:35.900 13-JUN-2008	ST1.TCSETUP.TC00	TRUE TO FALSE STATUS CHA	3599	52
14	10:18:55.910 13-JUN-2008	ST1.TCSETUP.TC01	TRUE TO FALSE STATUS CHA	3600	53

Field	Definition
Collect Data	Click here to start the audit collection.
Data Storage	Click here to call up the Data Storage Parameters dialog box. This can be used to set up the system so that copies of the audit log data currently being viewed, can be stored on your PC. See Section 6.2.1.
Search Criteria	Click here to call up the Select Data Collection Criteria dialog box. This can be used to filter the amount of data collected. See Section 6.2.2.


6.2.1 Data Storage



Note: This only saves a snapshot of the data you have actually viewed on the screen; it does NOT save the entire contents of the audit buffers. As you scroll to bring new data on the screen, it will be added to the specified file. If you want to save ALL Audit data, see Section 6.3

Field	Definition
Store Data on Collection	If checked, stores the current audit data in view in a file on the PC.
File	Specifies the path and filename of the audit file on the PC. You can use the [...] button to navigate to the appropriate path.
Create File	If checked, a new file is created for each collection.
Append File	If checked, new data from a collection is appended to an existing file.
Data Delimiter	Choose a format for the way the audit data entries will be separated in the file. Choices include a space, comma, or semi-colon.
Convert Data to Extended Format	Disabled for this application.
OK	Saves the changes made in this dialog box, and exits to return to the Station Audit Trail page.
Cancel	Exit the dialog box and return to the Station Audit Trail page, without saving changes.

6.2.2 Search Criteria



Field	Definition
Records	There are three possible choices here: Both Alarms & Events When this option is selected, both alarm and event data will be displayed. Events Only When this option is selected, only event data will be displayed. Alarms Only When this option is selected, only alarm data will be displayed.
Search Method	This dialog box allows you to filter the audit data which will be displayed. Collect All Available Records specifies that all audit data from this alarm and event buffer should be collected. Start Date will display a list box, from which you can select a particular date. Only audit data with timestamps on that date or newer than that date will be collected. Specified Period specifies that only audit data collected during the period you specify should be collected. Choices are 'Today', 'This Week', or 'This Month'.
Direction	Choose From Oldest to Newest to display the records chronologically with the oldest records at the top of the screen, and newest records towards the bottom. Choose From Newest to Oldest to display the records in reverse chronological order, with the newest records at the top of the screen, and oldest records towards the bottom.

OK	Saves the changes made in this dialog box, and exits to return to the Station Audit Trail page.
Cancel	Exit the dialog box and return to the Station Audit Trail page, without saving changes.

6.3 Collection

The Collection button provides another method for collecting, storing and viewing historical data. Many users find this method preferable to the individual View Archives and View Audit methods.

Historical Data Collection

Station Name
TEST_STATION

Storage Folder: C:\OpenBSI\Web\WaterApp\Logs

Type	Description	Log #	Target File
Archive	HOURLY	1	
Archive	DAILY	2	
Archive	TREND	3	
Audit	Audit	11	

Once the collection is started, it will continue until 'Stop Collection' is selected. The collected log may be viewed and saved to the specified location on the PC as a .CSV formatted file.

Field	Description
Station Name	This is typically the name of the controller. This name will be used as the file basename of the log file.
Storage Folder	This is the directory on the PC where the log files will be stored. This directory must exist. You can type in the folder name or use the [Browse] button to locate it.

Log selection window	The window in the center of the page displays details of the available data in the controller, which can be used to create log files. Included are the Type of data (audit, archive), a Description of the data, a "Log#" which identifies the archive file number (not applicable to audit), and Target File which shows the file extension which will be used for the log file. This window is also used to specify which logs you want to collect, view, or convert to CSV. To select a log, click on it. You can select multiple logs for collection by holding down the [Ctrl] key as you select. Once you have selected the logs, you can start the collection by clicking on [Start Collection]. The view and convert options can only be used on one log at a time.
[Start Collection]	When clicked will start collections of all selected logs. This button is disabled if collections are already in progress.
[Stop Collection]	When clicked, will terminate all underway collections. Note: This can result in incomplete data being stored in log files.
[View Storage]	When clicked, will display the contents of the currently selected log file in a separate window on the screen.
[Convert to CSV]	When clicked, will generate a comma separated variable (CSV) file, from the contents of the currently selected log file. This file will be created in the folder specified in the " Storage Folder " field. The filename will be the original file basename, followed by an underscore, followed by the original file extension, then (.CSV) for the extension. For example, the CSV file generated from the log file DAILY.DLY would be named DAILY_DLY.CSV.

Bristol ControlWave Pump Controller Application

**Emerson Process Management
Remote Automation Solutions**
1100 Buckingham Street
Watertown, CT 06795
Phone: +1 (860) 945-2262
Fax: +1 (860) 945-2525
www.EmersonProcess.com/Remote

**Emerson Process Management
Remote Automation Solutions**
6338 Viscount Rd.
Mississauga, Ont. L4V 1H3
Canada
Phone: 905-362-0880
Fax: 905-362-0882
www.EmersonProcess.com/Remote

Emerson Process Management Mexico
Viveros de la Colina No 238
Col. Viveros de la Loma
Tlalnepantla, Mexico 54080
T +52 (55) 57.28.08.00
F +52 (55) 53.66.26.18
www.EmersonProcess.com/Remote

**Emerson Process Management, Ltd.
Remote Automation Solutions**
Blackpole Road
Worcester, WR3 8YB
United Kingdom
Phone: +44 1905 856950
Fax: +44 1905 856969
www.EmersonProcess.com/Remote

**Emerson Process Management AP Pte Ltd.
Remote Automation Solutions Division**
1 Pandan Crescent
Singapore 128461
Phone: +65-6770-8584
Fax: +65-6891-7841
www.EmersonProcess.com/Remote

NOTICE

"Remote Automation Solutions ("RAS"), division of Emerson Process Management shall not be liable for technical or editorial errors in this manual or omissions from this manual. RAS MAKES NO WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE WITH RESPECT TO THIS MANUAL AND, IN NO EVENT SHALL RAS BE LIABLE FOR ANY INCIDENTAL, PUNITIVE, SPECIAL OR CONSEQUENTIAL DAMAGES INCLUDING, BUT NOT LIMITED TO, LOSS OF PRODUCTION, LOSS OF PROFITS, LOSS OF REVENUE OR USE AND COSTS INCURRED INCLUDING WITHOUT LIMITATION FOR CAPITAL, FUEL AND POWER, AND CLAIMS OF THIRD PARTIES. Bristol, Inc., Bristol Canada, BBI SA de CV and Emerson Process Management Ltd, Remote Automation Solutions division (UK), are wholly owned subsidiaries of Emerson Electric Co. doing business as Remote Automation Solutions ("RAS"), a division of Emerson Process Management. FloBoss, ROCLINK, Bristol, Bristol Babcock, ControlWave, TeleFlow and Helicoid are trademarks of RAS. AMS, PlantWeb and the PlantWeb logo are marks of Emerson Electric Co. The Emerson logo is a trademark and service mark of the Emerson Electric Co. All other trademarks are property of their respective owners. The contents of this publication are presented for informational purposes only. While every effort has been made to ensure informational accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. RAS reserves the right to modify or improve the designs or specifications of such products at any time without notice. All sales are governed by RAS' terms and conditions which are available upon request. RAS does not assume responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use and maintenance of any RAS product remains solely with the purchaser and end-user. "

© 2008 Remote Automation Solutions, division of Emerson Process Management. All rights reserved.