



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1680247 (LR 44092)

Master Contract: 152450

Project: 1680247

Date Issued: 2005/10/17

Issued to: **Micro Motion Incorporated**

**7070 Winchester Cir
Boulder, CO 80301
USA**

Attention: Ray Stengl

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Wesley Van Hill

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G

Model 2400 transmitter integrally mounted to existing sensors. Input Voltage 18-100Vdc, 85-250Vac; Pi = 7W;
Enclosure Type 4; Temperature Code = T4A; Ambient = -40°C to +60°C

APPLICABLE REQUIREMENTS

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1680247 (LR 44092)

Master Contract: 152450

Project: 1680247

Date Issued: 2005/10/17

CSA Standard C22.2 No. 0 M1991 - General Requirements - Canadian Electrical Code Part II.

CSA Standard C22.2 No. 0.4-M2004 - Bonding and Grounding of Electrical Equipment (Protective Grounding).

CSA Standard C22.2 No. 0.5-M1982 - Threaded Conduit Entries

CSA Standard C22.2 No. 25-M1966 - Enclosures for use in Class II Groups E, F and G Hazardous Locations

CSA Standard C22.2 No. 94-M1991 - Special Purpose Enclosures.

CSA Standard C22.2 No. 142-M1987 - Process Control Equipment.

CSA Standard C22.2 No. 213-M1987- Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.

UL 50, Eleventh Edition - Enclosures for Electrical Equipment

UL 508, Seventeenth Edition - Industrial Control Equipment.

UL 1203, Third Edition - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

UL 1604, Third Edition - Electrical Equipment for Use in Class I and II, Division 2, And Class III Hazardous (Classified) Locations.



Supplement to Certificate of Compliance

Certificate: 1680247

Master Contract: 152450

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1680247	2005/10/17	Model 2400 Transmitter (integrally mounted to existing sensors)