

Certificate of Compliance

Certificate: 1398050 (LR 44092)

Master Contract: 152450

Project: 1454570 (Edition 2)

Date Issued: July 27, 2003

Issued to: **Micro Motion Incorporated**
7070 Winchester Circle
Boulder, CO 80301
USA

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by:



Jay R McVeigh

Authorized by: Patricia Pasemko
Operations Manager

CLASS

2258 02 - PROCESS CONTROL EQUIPMENT - For use in Hazardous Locations

2258 82 - PROCESS CONTROL EQUIPMENT - For use in Hazardous Locations - Certified to U.S. Standards

PRODUCTS

Class I, Division 2, Groups A, B, C and D

Model 1500 and 2500 transmitters; rated 24Vdc, 6.3W maximum; Temperature Code T5; Max Ambient 40°C; Provides Intrinsically Safe connections to Model 700 Core Processor located in CI I, Div 1, Gr CD; CI I, Div 2; Gr ABCD; CI II, Gr EFG when connected as per Installation Instructions CSA-D-IS

Note: The Models 1500 and 2500 transmitters are a component only and must be installed in a suitable enclosure.



CSA INTERNATIONAL

Certificate: 1398050
Project: 1454570

Master Contract: 152450
Date: 2003-06-27

APPLICABLE REQUIREMENTS

C22.2 No 0 - M1991	General Requirements - Canadian Electrical Code Part II.
C22.2 No 0.4 - M1982	Bonding and Grounding of Electrical Equipment (Protective Grounding).
C22.2 No 142 - M1987	Process Control Equipment.
C22.2 No 157 - M1992	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations.
C22.2 No 213 - M1987	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.
UL 508, Seventeenth Edition	Industrial Control Equipment.
UL 698, Eleventh Edition	Industrial Control Equipment for Use in Hazardous (Classified) Locations.
UL 913, Sixth Edition	Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II, III, Division 1, Hazardous (Classified) Locations.
UL 1604, Third Edition	Electrical Equipment for Use in Class I and II, Division 2, And Class III Hazardous (Classified) Locations.



Supplement to Certificate of Compliance

Certificate: 1398050 (LR44092)

Master Contract: 152450

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1398050	2003-05-26	Original Certification of Model 2500 Transmitter for use in Hazardous Locations
1454570	July 27, 2003	Add Model 1500 Transmitter for use in Hazardous Locations