




the pressure equipment safety authority

STATUTORY DECLARATION
Registration of Fittings



I, Michael Zinn

Approval Manager

(company title, e.g. vice president, plant manager, chief engineer) (must be in a position of authority)

of Micro Motion, Inc.

(name of manufacturer)

located at 7070 Winchester CR, Boulder, CO 80301

(plant address)

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (check one)

[X] comply with the requirements of ASME B31.3 which specifies the dimensions, (title of recognized North American Standard)

materials of construction, pressure/temperature ratings and identification marking of the fittings, or

[] are not covered by the provisions of a recognized North American standard and are therefore manufactured to

comply with as supported by the attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified by the following authority, DNV as being suitable for the manufacture of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are CMFHC3(M, A or C)

In support of this application, the following information, calculations and/or test data are attached:

Tube Drawings and Calculations, Manifold Burst Tests

DECLARED before me at Boulder County in the State of Colorado

this 17th day of September, 2007 (Month) (Year)

(print) Leslie R. Stengel, Notary Public

Michael Zinn (Signature of Applicant)

(sign) Leslie R. Stengel (A Commissioner for Oaths)

My commission expires 8/16/2008

For Office Use Only NOTE: SEE SCOPE OF REGISTRATION L. 6

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Clause 4.2, and is accepted for registration in Category "F"

Registration Number: 0 F 08762 . 2

MILLA GRYNCHUK (For the Administrator/Chief Inspector of Alberta)

Date Registered: NOV 29 2007

Expiry Date: 2017-11-29

This registration covers the following Flow meters:

CMFHC3M 150/300/600 lb

CMFHC3A 150/300/600 lb

CMFHC3C 150/300/600 lb

Materials: Tubes ASTM A 269 316/316L

Manifold ASTM A351 CF-3M

Flange Standard – per B16.5

Flange non-standard MMI-20009590 Rev. A A-182 F316/316L

Pressure/temperature rating table is attached.

0 F 0 8 7 6 2 . 2

GENERAL NOTES: (UNLESS OTHERWISE SPECIFIED)

REV.	EDN.	DESCRIPTION OF CHANGE	DRAWN	CHKD	APVD	DATE

ALBERTA BOILERS SAFETY ASSOCIATION
 PROVINCE OF ALBERTA
 SAFETY CODES ACT


REGISTRATION NO.
0 F 08762

REGISTRATION NO. **CMFHC3M, CMFHC3A, CMFHC3C**

DWG. NO. or CAT. NO. **Flow Meters**

TYPE OF FITTINGS
NOV 29 2007

INITIALS **L.B.**



THIS COMPONENT MUST COMPLY WITH
 REGULATIONS OF THE PROVINCE OF ALBERTA.
 NO CHANGES ARE TO BE MADE WITHOUT
 PRIOR AUTHORIZATION FROM MICRO
 MOTION APPROVALS ENGINEERING.

copyright 2007 MICRO MOTION, INC.
 ALL RIGHTS RESERVED.

TITLE	DESCRIPTION	PART OR REF. NO.	MATERIAL	QTY.

NAME	DATE	SIZE	REV.

MICRO MOTION, INC.
 BOULDER, COLORADO

APPROVAL: CMFHC3 PED

DWG. NO. **0 F 08762**

REV. **A**

SCALE: 3:1